

Ph.: 011-25683304

Email: dgmosdtl@gmail.com

दिल्ली ट्रांसको लिमिटेड
DELHI TRANSCO LIMITED
Office of DGM (OS & Lines)
Convener (Operation Co-ordination Committee)
Room No. 10, 1st floor, 220KV S/ Stn. Bldg.,
Naraina, Ring Road, New Delhi-110010

No. F.DTL/831/F.4/2014-15/DGM (OS & Lines)/55

Date: 20.06.2014

To: **Members of Operation Co-ordination committee**

DTL	General Manager (O&M)-I Chairman OCC General Manager (O&M)-II GM (Planning) DGM (O&M)-I, II & III DGM(400kV) DGM (M/P) DGM(Plg.)	Fax no. 011-23366160 Fax No.011-23622707 Fax no. 011-23366160 Fax No.011-23632031
SLDC	General Manager (SLDC) DGM (SO)	Fax no. 011-23221069 Fax no. 011-23221059, 23221012
TPDDL	HOD (PSC &AM) Sr. Manager (PSC)	Fax no. 011-66050602 Fax no. 011-66050602
BRPL	Asstt. Vice President (SO)	Fax no. 011-39996549
BYPL	Dy. General Manager (SO)	Fax no. 011-39996549
NDMC	Superintending Engineer	Fax no. 011-23235754
IPGCL	DGM (I/C) RPH DGM (O) GTPS	
PPCL	DGM (O) PPCL	
MES	AEE/M.SLDC Officer	
BTPS	AGM (EEMG)	Fax no. 011-26944348
BBMB	Sr. Executive Engineer, O&M	Fax no. 011-28315542,
DMRC	DGM(Elect.)	

विषय: प्रचालन समन्वय उपसमिति आपात बैठक दिनांकित 19.06.2014 (गुरुवार) सुबह 11:00 बजे का कार्यवृत्त ।

Sub: MOM of Emergency OCC Meeting dated 19.06.2014 (Thursday) at 11:00 AM

प्रचालन समन्वय उपसमिति की आपात बैठक दिनांकित दिनांकित 19.06.2014 (गुरुवार) सुबह 11:00 बजे, प्रथम मंजिल, सम्मेलन कक्ष, एस एल डी सी भवन, मिंटो रोड, नई दिल्ली में आयोजित की गई। उक्त बैठक के कार्यवृत्त की एक प्रति सूचनार्थ व आवश्यक कार्यवाही हेतु इस पत्र के साथ संलग्न है।

The Emergency OCC meeting was held on dt. 19.06.2014 (Thursday) at 11:00 A.M. in the Conference Room, 1st Floor, SLDC Building, Minto Road, New Delhi. A copy of the minutes of meeting is enclosed herewith for favour of information and necessary action.

Sd/-
(लवलीन सिंह)
(Loveleen Singh)
उपमहाप्रबंधक (प्रचालन सेवाएं एवं लाइन्स)
Dy.General Manager (Operation Services & Lines)
संयोजक, प्रचालन समन्वय उपसमिति
Convener, Operation Coordination Committee

Enclosure:

प्रचालन समन्वय उपसमिति बैठक दिनांकित 19.06.2014 का कार्यवृत्त ।
MOM of OCC meeting dt.19.06.2014

DELHI TRANSCO LIMITED
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)
Office of Dy. Gen. Mgr. (OS & Lines)
220KV S/Stn. Bldg. Naraina, New Delhi-110010
Tele: 25683304

MINUTES OF EMERGENCY OCC MEETING DT. 19.06.2014

GM (O&M)-I, DTL, Chairman-Delhi OCC welcome the members and distinguished guests to the meeting. DGM (OS&L), DTL – Convener Delhi OCC informed that emergency OCC meeting has been called on to discuss emergency shut-down on 220kV Bamnauli – Pappankalan – I Ckt – I and 220kV Bamnauli – Pappankalan – II Ckt. – II simultaneously.

1. Shutdown of 220kV Bamnauli – Pappankalan – I Ckt – I and 220kV Bamnauli – Pappankalan – II Ckt. – I.

DTL proposed the shutdown of 220kV Bamnauli – Pappankalan – I Ckt – I and 220kV Bamnauli – Pappankalan – II Ckt. – I simultaneously on dt. 21.05.2014 from 0600Hrs to 1500Hrs to shift the conductor on to newly erected towers.

Delhi OCC deliberated the modalities of shutdown with BRPL and DMRC. After deliberation, OCC approved the said shutdown of 220kV Bamnauli – Pappankalan – I Ckt – I and 220kV Bamnauli – Pappankalan – II Ckt. – I on dt. 21/06/2014 between 05:00Hrs to 14:00Hrs.

The procedure for availing shutdown is as below:

- Shutdown of 220kV Bamnauli – Pappankalan – I, Ckts. – I & II (as, ckt. II is also charged on no load) will be availed for repair/fixing of 2 nos. tower peaks and earth wire. The damaged peaks of Tower # 6 and Tower # 14 shall be replaced and the stringing of earth wire between Tower # 6 Tower # 17 will be done.
- Thereafter, Ckt – I of 220kV Bamnauli – Pappankalan–I line, will be energized.
- Further, shutdown of Ckt. – I of 220kV Bamnauli – Pappankalan – II will be taken for removal of T-off jumpers which were provided to facilitate charging of ckt. II of Pappankalan–I line. During this shutdown, the following procedure will be followed:
 - Initially the removal of jumpers from tower (at T-Off point) of Ckt-II of Pappankalan-I line will be carried out.
 - Then, Ckt-II of Pappankalan-I line will be got energized.
 - Thereafter, normalization of jumpers (at T-Off point) of Ckt-I of Pappankalan-II line will be carried out.
 - Finally, Ckt.-I of Pappankalan-II line will be got energized.

OCC advised SLDC, BRPL and DMRC to manage the outages for any contingency arising out due to transient tripping on any of the remaining circuits.

(Action by DTL, BRPL and DMRC)

2. Removal of LILO at 220kV Maharani Bagh on 220kV Pragati – Sarita Vihar line.

DTL informed that the work of 220kV Maharani Bagh – Gazipur line is in full swing and expected to be completed by 23rd June, 2014. Before completion of the erection work of the said line, LILO at 220kV Maharani Bagh on 220kV Pragati – Sarita Vihar needs to be removed. After the removal of jumpers at Tower #12 there will not be any link between Maharani and Pragati, Maharani Bagh and Sarita Vihar S/stns. The removal of LILO at 220kV Maharani Bagh on 220kV Pragati – Sarita Vihar line is required to accommodate spared bays for 220kV Maharani Bagh – Gazipur Double Circuit line.

Delhi OCC deliberated the same. After Deliberation, OCC approved the shutdown of 220kV Pragati – Sarit Vihar line on dt. 22.06.14 from 0600Hrs to 1100Hrs for removal of jumpers at Tower # 12 i.e. LILO point to 220kV Maharani Bagh S/Stn.

(Action by DTL, SLDC)

3. Requirement of 2nos. 66kV feeder bays by BRPL at 220kV DIAL.

BRPL requested DTL to provide 2 nos., 66kV bays at 220kV DIAL substation of DTL so that portion of the BRPL load on 220kV Pappankalan –I & II substations can be shifted to 220kV DIAL substation, this is in order to reduce the load stress on these substations.

Delhi OCC deliberated the same and advised BRPL to take up the issue with Delhi Steering Committee for allocation of above referred bays.

(Action by BRPL)

Meeting ended with vote of thanks to the Chair.

Attendance sheet of Emergency OCC Meeting held on 19.06.14 at 11:00 A.M. in the Conference Room, SLDC Building, Minto Road, New Delhi.

S.No.	Name (Sh.)	Designation	Company	Mobile No.	e-mail Id.	Sign.
1.	Bran Parakar	GM(O&M)-I	DTL	9999533630	Chair	
2.	Md. Shadab Ahmad	AM	TP DDL	9717991935	mdshadab.ahmad@ozdp.com	Shadab
3.	Munirul Haq	Manager (S)	DTL	9999533843	munirulhaq@pwr.com	
4.	Shyamal Sathadhara	DGM(O&M)	DTL	9999533671	Shyamal.Sathadhara@dtl.gov.in	
5.	P. Devanand	Asstt	TP DDL	9871800526	p.devanand@ndpl.com	
6.	PANKU MARR	Asstt (T) O&M	DTL	9999533998	PANKU MARR-TANWAR	
7.	Pavan Kr. P	Asstt-1	PHCC	9110226620	Pavan - P233@gmail.com	
8.	Arshidul Javed	Asstt P.	RRPL	9321147809	Arshidul.Javed@relsonicada.com	
9.	P.N. Gupta	Comptroller	DTL	9999533826	psdpr2012@gmail.com	
10.	L.P. KISHINATH	DGM (T)	DTL	9899533269	L.P.K.S.B.B@fodelfmoad.com	
11.	H. VYAS	GMD	DTL	9999532631	hazijane.dtl.gov.in	
12.	Lokesh Singh	DCM(O&M)	DTL	9999533659	dgm.os@dtl.gov.in	
13.	Rajesh K. Raghavella	AM(T)-IS	DTL	9999533866	R.K.Raghavella@dtl.gov.in	
14.						
15.						
16.						
17.						
18.						
19.						