

DELHI TRANSCO LIMITED
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)
Office of Dy. Gen. Mgr. (OS)

MINUTES OF THE EMERGENCY OCC MEETING DT. 29.07.2015

ED(Tech) O&M-I, DTL, Chairman-Delhi OCC welcomed all the members of OCC and distinguished guests to the meeting.

List of participants is enclosed.

The point-wised deliberations made during the meeting are as below:

1.0 Emergency Shutdown of 220kV GIS Bus bar – I&II at 220kV Kahmere Gate S/Stn.

DTL proposed the following emergency shutdown of 220kV GIS Bus bar – I & II at 220kV Kashmere Gate Substation to attend SF6 leakage in Y-phase compartment of Bus-II isolator, 220kV South of Wazirabad Ckt-I bay.

The shutdown has been deliberated in the OCC and representatives of DMRC, BYPL and TPDDL agreed for the shutdown on *dt. 02.08.15(Sunday) from 10:00Hrs. to 16:00Hrs.* OCC approved the shutdown subject to the following:

- 33kV Civil Line Ckts.-I&II at Kashmere Gate Substation will be back-fed from 33kV Civil Lines substation of TPDDL. Station load shall be met through this arrangement.
- 11kV feeder of BYPL i.e. 11kV Electric Crematorium shall be kept in charged condition through 33/11kV 20MVA Transformer at Kashmere Gate.
- No shutdown will be permitted at 220kV Gopalpur substation during this period.
- Remaining Load shall be managed by DISCOMs and DMRC.
- Shutdown shall be applied by 08:00Hrs. so that all the changeover required shall be carried up to 09:00Hrs. on dt. 02.08.15.
- DMRC requested to clear the shutdown prior to peak hours i.e. 17:00Hrs.

Further, OCC advised DMRC to carry out any maintenance activities on 220kV K.Gate-DMRC Ckts-I&II at their end during the said shutdown period.

(Action by DTL, DMRC, BYPL, TPDDL)

2.0 Proposed Shutdown by DTL O&M for inspection of 33kV GIS at 220kV K. Gate S/Stn. by OEM Engineer from Germany.

OCC deliberated and approved the following shutdown proposed by DTL at 220kV Kashmere Gate Substation for carrying inspection of 33kV GIS by M/s ABB i.e. OEM.

S. No.	Proposed Date of S/D	Name of the feeder / equipment	Work to be carried out	Approved Date of S/D
1	05.10.2015	33kV Civil Line Ckt-I	Inspection/ Checking of switchgears	05.10.2015
2	06.10.2015	33kV Fountain		06.10.2015
3	07.10.2015	33kV Lahori Gate		07.10.2015
4	08.10.2015	33/11kV 16MVA Transformer		08.10.2015
5	09.10.2015	33/11kV 20MVA Transformer		09.10.2015
6	10.10.2015	33kV Jama Masjid		10.10.2015
7	11.10.2015	33kV Civil Line Ckt. -II and 33kV Town Hall		11.10.2015
8	12.10.2015	33kV I/C-1 from 100MVA Tx-I and Bus section-II		12.10.2015
9	13.10.2015	33kV I/C-2 from 100MVA Tx-I and Bus section-I		13.10.2015
10	14.10.2015	33kV Bus coupler and Bus PT Panel		14.10.2015

(Action by DTL)

3.0 Meeting ended with vote of thanks to the chair.

Special OCC Meeting held in the Chamber of ED (O&M-I) on date 29-07-15

Sr.No	Name & Designation	Name of Company	E-mail / contact No.
1.	S.K. SARKAR	DTL	Gmommth@gmail.com.
2	Brijesh Kr.	DTL	manger_icm@yahoo.com 999533825
3	Pavan Kumar	DMRC	pavan.p233@gmail.com 9910226560
4.	S. Sutradhan	DTL	mgr. omvi@rediffmail.com 999533671
5.	R. S Meena	DTL	dfm402k@yahoo.com 999533665
6.	B.L. Gujar	DTL	bl.gujar@dtl.gov.in 9999533985
7	R.P. Aggarwal	BYPL	Rajendra.Aggarwal@relianceada.com
8.	Som Dutt	BYPL	som.dutt@relianceada.com.
9.	Kamlesh DM	DTL	kdamth@gmail.com
10	Md. Shadab Ahmad	TPDDL	mdshadab.ahmad@ndpl.com
11	Sonjeev Kumar	SLDC	
12	Rajesh Kr. Pachigolla	DTL	rk.pachigolla@dtl.gov.in 999533866

Special OCC Meeting held in the Chamber of ED (O&M-I) on date 29-07-15

Sr.No	Name & Designation	Name of Company	E-mail / contact No.
13	L.P. KUSHINATHA	DTL S&M	lpk@bcm@rediffmail.com 9989533664
14	SHARIFA IABAL	DTL OS	Mgrossdtl@gmail.com
3	Pavani Kumar	DTL	pavani.kumar@rediffmail.com 9989533664
4	S. Subashini	DTL	subashini@rediffmail.com 9989533664
5	K. Srinivas	DTL	srinivas@rediffmail.com 9989533664
6	B.L. Gupta	DTL	blg@rediffmail.com 9989533664
7	H.P. Anand	DTL	anand@rediffmail.com 9989533664
8	Hemant	DTL	hemant@rediffmail.com 9989533664
9	Kamalaiah	DTL	kamalaiah@rediffmail.com 9989533664
10	M. Sadik Ahmad	DTL	sadik@rediffmail.com 9989533664
11	Sanjay Kumar	DTL	sanjay@rediffmail.com 9989533664
12	Rajesh K. Sathiyamoorthy	DTL	rajesh@rediffmail.com 9989533664