



No. F.DTL/201/2021-22/DGM(OS)/ 165

Date: 22.12.2021

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM (DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee


Sub: Agenda for 9th Delhi OCC Meeting (2021-22) to be held on 28.12.2021 at 11:00 A.M. through video conferencing.

The 9th Delhi OCC meeting (2021-22) is scheduled to be held on dt.- **28.12.2021, 11:00 A.M** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,



22/12/2021

Hitesh Kumar
DGM(T)OS, DTL

DELHI TRANSCO LIMITED
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 09/2021-22

Date : 28 .12.2021
Time : 11:00 AM
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 8th Delhi OCC meeting (2021-22) held on dated 29.11.2021.

The 8th Delhi OCC meeting (2021-22) was held on 29.11.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 18.11.2021. Minutes of the OCC meeting were issued on 03.12.2021 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of January-2022.

DTL proposed planned shutdowns for the month of January-2022 (Annexure-I).

(OCC may deliberate)

3. Shutdowns requested by PGCIL for complete 220kV GIS Dwarka Sub-station for coating of relay card.

DTL, O&M-I division forwarded the following shutdowns to consider discussing in OCC meeting is as under:-

SN.	Bus Section	Name of DTL Line	Shutdown Period
1	Bus Section 'A'	160MVA ICT-I & II (Future bay) Dwarka-PPK-II U/G cable Ckt-I & II (upcoming) Dwarka-Naraina O/H Ckt-II Dwarka-PPK-I U/G Ckt-II Bus Coupler-I Dwarka-Naraina O/H Ckt-I Dwarka-PPK-I U/G Ckt-II Bus Sectionalizer-I	05.01.2022 (08:00 hrs to 20:00 hrs)

2.	Bus Section 'B'	Bus Sectionalizer-II Dwarka-PPK-III Ckt-I&II Bus Coupler-II Spare Bay 160MVA ICT-III&IV (Future)	05.01.2022 (08:00 hrs to 20:00 hrs)
----	-----------------	--	--

(OCC may deliberate)

BRPL Agenda:-

4. High 11kV bus-bar Voltage at 220kV Okhla, Mehrauli & Sarita Vihar Sub-stations. .

11kV Bus-bar voltage at these stations approaching 12kV. BRPL requested SLDC to reduce tap positions from 5 to 3 on 66/11kV PTR's. High voltage complaints are very frequent in area feeding from above 220kV Sub-stations. Very high voltage is threat to our system and possibility of flashover in distribution system.

OCC is requested to deliberate the high voltage issue.

(OCC may deliberate)

5. Non-availability of 66 kV bus selection scheme at 220kV Najafgarh.

At 220kV Najafgarh Sub-station, 66kV Nangloi & 66kV Jaffarpur Ckt with 20MVA PTR-III is not available with bus selection scheme. This is a major concern keeping in view of the summer loading.

At 220kV Najafgarh Sub-station, there was a scheme to strengthen 66kV bus bar system. OCC is requested to deliberate the same.

(OCC may deliberate)

BYPL Agenda:-

6. Feeder wise metering for Reactive energy billing.

It is requested that for reactive energy billing, feeder wise metering be done for each trunk feeder supplying BYPL areas as this will help identify particular feeders where reactive energy penalties are on higher side.

Keeping in view of high reactive energy penalties during off peak months, SLDC is also requested to kindly share the day wise breakup of total MUs in monthly reactive energy bills. This is required for analysis purpose to identify high reactive energy penalty days.

(OCC may deliberate)

7. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 16.12.2021
1.	220kV PEERAGARHI - 33kV A-4 PASCHIM VIHAR CKT.	BRPL	10.07.21	'Y' PH. SINGLE CABLE CONNECTOR FAULTY.
2.	220kV OKHLA - 33kV EAST OF KAILASH CKT.	BRPL	25.08.21	'R' PH. SINGLE CABLE FAULTY.
3.	220kV PPK-II - 66kV HASTAL CKT.-I	BRPL	18.10.21	'B' PH. SINGLE CABLE FAULTY.
4.	220kV LODHI ROAD - 33kV NDSE CKT.	BRPL	29.11.21	'R' PH. SINGLE CABLE FAULTY.
5.	220kV PPK-II - 66kV HASTAL CKT.-II	BRPL	11.12.21	'B' PH. SINGLE CABLE FAULTY.
6.	33kV BAY -1 (IP - KILOKRI)	BRPL	15.12.21	'B' PH. SINGLE CABLE FAULTY.
7.	22kV GAZIPUR - 66kV PPG INDL. AREA CKT.	BYPL	11.12.21	'R' & 'Y' PH.CABLE FAULTY
8.	33kV BAY -28 (IP- CONNAUGHT PLACE)	NDMC	17.10.21	'R' PH. CABLE FAULTY
9.	400kV BAWANA, 315MVA ICT-II	DTL	30.03.21	315MVA ICT-II CAUGHT FIRE AND DAMAGED.
10.	AT PEERAGARHI: - 220/33kV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFFERENTIAL. TX FAULTY.
11.	220kV LODHI ROAD - 33kV DEFENCE COLONY CKT.	DTL	30.09.21	BREAKER PROBLEM.
12.	220kV PARK STREET - 66kV DMRC CKT.-I&-II	DTL/ DMRC	19.10.21	SHUT DOWN FOR GRID SHIFTING WORK AT DMRC END.
13.	At ROHINI I:- 220/66KV 100MVA TR.-II	DTL	11.11.21	SHUT DOWN FOR OVERHAULING OF TRANSFORMER.
14.	AT MUNDKA: 315MVA ICT - IV	DTL	13.11.21	TRIPPED ON BUCHLOZ RELAY. 'R' PH. WINDING DAMAGED.

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 16.12.2021
15.	220kV MAHARANI BAGH - TRAUMA CENTRE CKT.-I&II	DTL	15.11.21	SHUT DOWN FOR JOINTING WORK OF NEW CABLE BETWEEN J.N. -05 AND JB -06 FOR PWD WORKS.
16.	AT MEHRAULI: 20MVA PR.TR.-I	DTL	19.11.21	SHUT DOWN FOR OVERHAULING OF TRANSFORMER.
17.	AT TRAUMA CENTRE: 220/33kV 100MVA PR. TR.-I	DTL	22.11.21	SHUT DOWN FOR OVERHAULING OF TRANSFORMER.
18.	220kV LODHI ROAD - ALL 33kV FEEDERS	DTL	29.11.21	ALL 33kV FEEDERS AFFECTED DUE TO BOTH 33kV BUSES DEAD BECAUSE OF FIRE IN 33kV GIS.
19.	AT SUBZI MANDI:- 33/11kV 16MVA TR-II	DTL	03.12.21	SHUT DOWN FOR OVERHAULING OF TRANSFORMER.
20.	220kV PPK -II - BAMNAULI CKT.-II	DTL	13.12.21	SHUT DOWN FOR OVERHAULING OF CKT. BREAKER.
