



No. F.DTL/201/2021-22/DGM-(OS)/ OCC /158

Date:- 03.12 .2021

**Subject: 08th Meeting of Delhi Operation Coordination Committee (2021-22)
- Minutes of Meeting.**

The 08th meeting of Delhi Operation Coordination Committee (OCC) was held on 29.11.2021 (Monday), 11:00 A.M and conducted through online mode.

The Minutes of Meeting are enclosed for information and necessary action.

Minutes of Meeting are also available on DTL website, www.dtl.gov.in under the tab "News and Information"-OCC Meeting. (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Thanking You.

Sincerely yours,

---Sd/--

(Hitesh Kumar)

Dy. General Manager (OS)

Delhi Transco Limited

Copy for favor of kind information to:

- (i) Secretary, DERC, Viniyamak Bhawan, C-Block, Shivalik, New Delhi-17
- (ii) OSD to CMD, DTL
- (iii) Director (Operation), DTL


03/12/2021
Dy. General Manager (OS)

To all members -- As per list enclosed --

08th Meeting of Delhi Operation Coordination Committee (2021-22)- Minutes of Meeting

Distribution List:

DTL	1. E.D.(Project-II): For early revival of 220 kV M.Bagh - Trauma Centre Ckts in view of shutdown proposed at agenda point no.04. 2. General Manager (O&M)-I 3. General Manager (O&M)-II 4. General Manager (P&M, DM&S) 5. General Manager (Planning) 6. DGM (O&M) - North, East, West, South 7. DGM (Metering/Protection) 8. DGM (Planning)
SLDC	1. General Manager (SLDC) 2. DGM (SO)
TPDDL	HOD (PSC &AM), Sr. Manager (PSC)
BRPL	VP, AVP (SO)
BYPL	VP, AVP (SO)
NDMC	Superintending Engineer, E-1
IPGCL	AGM (T) Opr. GTPS
PPCL	1. AGM (T) Opr.PPS-I 2. AGM (T) Opr. PPS-III
MES	AEE/M.SLDC Officer
BBMB	Sr. Executive Engineer, O&M
DMRC	GM (Traction), Sr.DGM (Traction)
GMR(DIAL)	GM(DIAL)
N. Railways	Sr. DEE (TRD)

Minutes of 08th Delhi OCC Meeting held on 29.11.2021

Date :	29.11.2021
Time:	11:00 AM
Venue:	Online Via Video conferencing O/o-GM(O&M)-I, Delhi Transco Ltd., 220 kV S/stn Park Street, New Delhi-01
	List of participants is enclosed as Annexure-I.

The Chairman, OCC welcomed the members/ participants and requested to start the meeting as per circulated agenda.

It was informed that the peak demand for October'21 was 5391 MW against peak demand of 4820 MW in October'20 and total energy consumed in October'21 was 2661.446 MUs against energy consumed 2450.274 MUs in October'2020. SLDC Delhi informed that, anticipated peak demand for the month of December'21 is 5250MW and expected availability is 5088 MW (Deficit -162MW). The anticipated maximum energy requirement for one day is 72.58MUs and expected availability is 114.461MUs (Surplus +41.881MUs).

1. Confirmation of minutes of 07th Delhi OCC meeting (2021-22) held on dated 26.10.2021.

The 7th Delhi OCC meeting (2021-22) was held on 26.10.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 18.10.2021 & 29.10.2021. Minutes of the OCC meeting were issued on 01.11.2021 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Members confirmed the minutes of 07th OCC meeting.

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of December-2021.

After detailed discussion with the members, OCC approved shutdowns subject to real time condition & consent from respective DISCOMs.

3. Issuance of PTW.

In OCC meeting held on 23.09.2021, A sub-committee was formed to resolve the issue of PTW during shutdown/breakdowns of 11kV, 33kV & 66kV feeders of DISCOMs.

During OCC meeting dt:26.10.2021, it was informed that an online meeting of this sub-committee was convened on 21.10.2021 and various issues in connection with issuance of PTW of outgoing feeders of distribution companies from DTL sub-stations were deliberated. OCC advised to submit the report in next OCC meeting.

The above sub-committee convened another meeting on 16.11.2021, the recommendations of sub-committee are reproduced are as under:

“Various prospective challenges, present practices and procedure in connection with issuance of PTW of outgoing feeders of Distribution companies from DTL sub stations were discussed and deliberated. Based on deliberations of the committee, it has been felt that the present procedure of availing shutdown from DTL sub stations may be continued.”

After deliberations, the OCC accepted the recommendations of sub-committee for continuing the procedure of availing of shutdown from DTL substations as per present practice.

4. Shutdowns requested by PGCIL for stringing of 400kV conductor for LILO of S/C 400 kV Bamnauli - Jhatikalan Transmission Line at 400 kV substation Dwarka.

DTL, O&M-I division forwarded the following shutdowns to consider discussing in OCC meeting is as under:-

SN.	Name of DTL Line	Shutdown Period	Tower Location
1	a) D/C Bamnauli-PPK-I Line b) D/C Dwarka-PPK-III Line	05.12.2021 to 07.12.2021 (03 days)	AP25-AP26 and AP 28-AP29
2	a) D/C Bamnauli – NJF Line b) D/C Bamnauli-PPK-I Line c) D/C Bamnauli-PPK-II Line	25.11.2021 to 26.11.2021 (02 days)	AP5-AP6
3	a) D/C Bamnauli-PPK-I b) D/C Bamnauli-PPK-III Line	01.12.2021 to 03.12.2021 (03 days)	AP14–AP15

PGCIL informed that, the work related to shutdown proposed at Sr No-2 has already been completed through hotline procedure.

SLDC apprised that, availability of 220 kV Naraina-Ridge Valley ckt is a must during shutdown of Bamnauli-PPK-I/ PPK-III ckts for reliability of system in Bamnauli-Dwarka-Naraina-R.Valley corridor.

As 220 kV Naraina-Ridge Valley ckt is a U/G cable and during winter season U/G cables are highly prone to tripping due to overvoltage condition in the network. Therefore, to

avail the PGCIL shutdowns the availability of 220 kV D/C Maharani Bagh-Trauma centre ckts must be considered which is already under S/D since 15.11.2021.

As gathered from DTL project-II, the 220 kV D/C Maharani Bagh - Trauma centre ckts are expected to be energized by 15.12.2021.

After detailed deliberation among members of DTL, DISCOMs, SLDC a revised schedule was proposed by PGCIL as below:-

SN.	Name of DTL Line	Shutdown Period
1.	D/C Bamnauli-PPK-I Line	17.12.2021 to 19.12.2021 (03 days)
2.	D/C Bamnauli-PPK-III Line	20.12.2021 to 22.12.2021 (03 days)
3.	D/C Bamnauli-PPK-III Line & D/C Bamnauli-PPK-I Line	26.12.2021 (01 day)

OCC opined that, the above shutdowns are approved on real time basis subject to the revival of 220kV Maharani Bagh-Trauma Centre Ckt-I & II.

(Action by DTL Project-II, PGCIL)

5. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 29.11.2021
1.	220kV PEERAGARHI - 33kV A-4 PASCHIM VIHAR CKT.	BRPL	10.07.21	SINGLE CABLE CONNECTOR FAULTY. Expected by 30.12.2021.
2.	220kV OKHLA - 33kV EAST OF KAILASH CKT.	BRPL	25.08.21	'R' PH. SINGLE CABLE FAULTY. Expected by 15.12.2021.
3.	220kV OKHLA - 33kV NEHRU PLACE CKT.-I	BRPL	27.10.21	'B' PH. SINGLE CABLE FAULTY. Expected by 20.12.2021.
4.	220kV PPK-II - 66kV HASTAL CKT.-I	BRPL	18.10.21	'B' PH. SINGLE CABLE FAULTY. Expected by 15.12.2021.
5.	220kV NAJAFGARH - BODELLA -II CKT.-II	BRPL	15.11.21	'R' PH. SINGLE CABLE FAULTY. Energized on 17.11.2021.
6.	220kV NAJAFGARH - BODELLA -II CKT.-I	BRPL	15.11.21	'B' PH. SINGLE CABLE FAULTY. Energized on 25.11.2021.
7.	220kV PATPARGANJ - 66kV VIVEK VIHAR CKT.-II	BYPL	10.11.21	'B' PH. CABLE FAULTY. Energized on 24.11.2021.
8.	220kV DSIDC BAWANA - 66kV	TPDDL	12.11.21	CABLE FAULTY. Ckt Energized.

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 29.11.2021
	BAWANA -1 CKT.-I			
9.	33kV BAY - 16 (IP - NIRMAN BHAWAN)	NDMC	01.08.21	'R' PH. CABLE FAULTY. Expected by 07.12.2021.
10.	33kV BAY -28 (IP-CONNAUGHT PLACE)	NDMC	17.10.21	'R' PH. CABLE FAULTY. Expected by 15.12.2021.
11.	33kV PARK STREET - NIRMAN BHAWAN CKT.	NDMC	02.11.21	'R' & 'Y' PH. CABLE FAULTY. Expected by 07.12.2021.
12.	400kV BAWANA, 315MVA ICT-II	DTL	30.03.21	315MVA ICT-II CAUGHT FIRE AND DAMAGED. Expected by 15.02.2021.
13.	AT PEERAGARHI: - 220/33kV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFF. TX FAULTY. Expected by March-2022.
14.	220kV LODHI ROAD - 33kV DEFENCE COLONY CKT.	DTL	30.09.21	BREAKER PROBLEM. The ckt revival is under progress.
15.	AT PPK -I : 20MVA PR.TR.-III	DTL	20.10.21	SHUT DOWN FOR OVER-HAULING OF TRANSFORMER. Energized on 24.11.2021.
16.	AT PPK -II : 220/66kV 100MVA PR.TR.-II	DTL	15.11.21	SHUT DOWN FOR OVER-HAULING OF CKT. BREAKER. Energized on 20.11.2021.
17.	220kV MAHARANI BAGH - TRAUMA CENTRE CKT.-I&II	DTL	15.11.21	SHUT DOWN FOR JOINTING WORK OF NEW CABLE BETWEEN J.N. -05 AND JB -06 FOR PWD WORKS. Expected by 15.12.2021.
18.	220kV BAMNAULI - DIAL CKT.-I & -II	DTL	09.11.21	SHUT DOWN FOR NHAI MONOPOLE ERECTION WORKS. Energized on 29.11.2021.
19.	220kV BTPS - OKHLA CKT.-II	DTL	15.11.21	SHUT DOWN FOR OVER-HAULING OF CKT. BREAKER. Energized on 19.11.2021.
20.	220kV PARK STREET - 66kV DMRC CKT.-I&-II	DTL	19.10.21	SHUT DOWN FOR GRID SHIFTING WORK AT DMRC END. Expected by March-2022.

The meeting ended with thanks to the Chair.
