



No. F.DTL/201/2021-22/DGM-(OS)/ OCC / 146

Date:- 29.10.2021

**Subject: 07th Meeting of Delhi Operation Coordination Committee (2021-22)
- Minutes of Meeting.**

The 07th meeting of Delhi Operation Coordination Committee (OCC) was held on 26.10.2021 (Tuesday), 11:00 A.M and conducted through online mode.

The Minutes of Meeting are enclosed for information and necessary action.

Minutes of Meeting are also available on DTL website, www.dtl.gov.in under the tab "News and Information"-OCC Meeting. (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Thanking You.

Sincerely yours,

---Sd/--


(Hitesh Kumar)

Dy. General Manager (OS)

Delhi Transco Limited

Copy for favor of kind information to:

- (i) Secretary, DERC, Viniyamak Bhawan, C-Block, Shivalik, New Delhi-17
- (ii) OSD to CMD, DTL
- (iii) Director (Operation), DTL


29/10/2021
Dy. General Manager (OS)

To all members -- As per list enclosed --

07th Meeting of Delhi Operation Coordination Committee (2021-22)- Minutes of Meeting

Distribution List:

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)
SLDC	General Manager (SLDC) DGM (SO)
TPDDL	HOD (PSC &AM), Sr. Manager (PSC)
BRPL	VP, AVP (SO)
BYPL	VP, AVP (SO)
NDMC	Superintending Engineer, E-1
IPGCL	AGM (T) Opr. GTPS
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III
MES	AEE/M.SLDC Officer
BBMB	Sr. Executive Engineer, O&M
DMRC	GM (Traction), Sr.DGM (Traction)
GMR(DIAL)	GM(DIAL)
N. Railways	Sr. DEE (TRD)

Minutes of 07th Delhi OCC Meeting held on 26.10.2021

Date :	26.10.2021
Time:	11:00 AM
Venue:	Online Via Video conferencing O/o-GM(O&M)-I, Delhi Transco Ltd., 220 kV S/stn Park Street, New Delhi-01
	List of participants is enclosed as Annexure-I.

The Chairman, OCC welcomed the members/ participants and requested to start the meeting as per circulated agenda.

It was informed that the peak demand for September'21 was 5548 MW against peak demand of 6231 MW in September'20 and total energy consumed in September'21 was 3024.735 MUs against energy consumed 3342.312 MUs in September'2020. SLDC Delhi informed that, anticipated peak demand for the month of November'21 is 3800MW and expected availability is 4904 MW (Surplus +1104). The anticipated maximum energy requirement for one day is 65MUs and expected availability is 107.905MUs (Surplus +42.905MUs).

1. Confirmation of minutes of 6th Delhi OCC meeting (2021-22) held on dated 23.09.2021.

The 6th Delhi OCC meeting (2021-22) was held on 23.09.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 16.09.2021 & 20.09.2021. Minutes of the OCC meeting were issued on 01.10.2021 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Members confirmed the minutes of 6th OCC meeting.

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of November-2021.

DTL proposed planned shutdowns for the month of November-2021. After detailed discussion with the members, OCC approved shutdowns subject to real time condition & consent from respective DISCOMs.

- SLDC stated that, major shutdown work at Lodhi Road (by NCRTC), Trauma Centre (by DTL Project) and DIAL (by NHAI & DTL) may affect other planned shutdowns in these corridors. Therefore, limited planned shutdowns will be given for these corridor.
- Shutdown of 220 kV Bus-A, C & E at Bamnauli of DTL Project Deptt. is approved from 02.12.2021 subject to revival of Maharani Bagh-Trauma Centre Ckt-I & II, which is scheduled in November.

3. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S.no.	Element's Name	ASSET	Date of outage	Status of outage as on 26.10.2021
1.	220kV PEERAGARHI - 33kV A-4 PASCHIM VIHAR CKT.	DTL/ BRPL	10.07.21	'Y' PH. SINGLE CABLE CONNECTOR FAULTY. A meeting was conducted on 18.10.21 & this case is handed over to BRPL. MOM enclosed as Annexure-III.
2.	220kV OKHLA - 33kV EAST OF KAILASH CKT.	BRPL	25.08.21	'R' PH. SINGLE CABLE FAULTY. Expected by 31.10.2021.
3.	33kV BAY -5 (IP - LAJPAT NAGAR)	BRPL	10.10.21	'R' PH. BOTH CABLE FAULTY. Energized on 23.10.2021.
4.	33kV LODHI ROAD - HUDCO CKT.	BRPL	12.10.21	'R' PH. SINGLE CABLE FAULTY. Energized on 19.10.2021.
5.	33kV PREET VIHAR - SHAKKARPUR CKT.	BYPL	15.10.21	'R' PH. CABLE FAULTY. Energized on 17.10.2021.
6.	33kV BAY - 16 (IP - NIRMAN BHAWAN)	NDMC	01.08.21	'R' PH. CABLE FAULTY. Expected by 10.11.2021.
7.	66kV GT - VIDYUT BHAWAN CKT.-I	NDMC	05.10.21	'R' PH. CABLE FAULTY. Expected by 05.11.2021.
8.	400kV BAWANA : 315MVA ICT-II	DTL	30.03.21	315MVA ICT-II CAUGHT FIRE AND DAMAGED. Expected by 31.12.21.
9.	AT PEERAGARHI: - 220/33kV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFFERENTIAL. Expected by 31.03.2022.

S.no.	Element's Name	ASSET	Date of outage	Status of outage as on 26.10.2021
10.	AT MASJID MOTH : 220/33kV 100MVA PR.TR.-II	DTL	21.09.21	TX UNDER OVERHAULING SINCE 23.09.2021. Expected by 31.10.2021.
11.	220kV LODHI ROAD - 33kV DEFENCE COLONY CKT.	DTL	30.09.21	BREAKER PROBLEM. Problem in GIS, revival of the feeder is under progress.
12.	AT NAJAFGARH: 20MVA PR.TR.-I	DTL	01.10.21	SHUT DOWN FOR COMPLETE OVERHAULING. Expected by 31.10.2021.
13.	AT NARAINA: 16MVA PR.TR.-I	DTL	04.10.21	SHUT DOWN FOR REPLACEMENT OF BCU & OVERHAULING OF TRANSFORMER. Expected by 01.11.2021.
14.	400kV MANDOLA - 220kV WAZIRABAD CKT.-III	DTL	17.10.21	SHUTDOWN FOR DMRC WORK. Energized on 27.10.2021.
15.	400kV MANDOLA - 220kV WAZIRABAD CKT.-IV	DTL	17.10.21	SHUTDOWN FOR DMRC WORK. Energized on 27.10.2021.

Additional Agenda

BYPL Agenda:-

1. Control of High voltage level in network during winter season.

1. Reactive energy above 103% voltage level is beyond our control & voltage received from DTL is also on higher side. This could be minimized through installation of reactors.
2. Tap changing at DTL grids will also help in maintaining suitable voltage level in BYPL grids.

BYPL requests DTL to kindly share update of installation of reactors at its grid locations with expected time frame. It is also requested to plan for further reducing tap of transformers at DTL grids, if required to regulate voltage level at BYPL grids.

DTL shared the status of installation of reactors at its various grids and attached as annexure-II.

OCC advised SLDC to take necessary steps for maintaining voltage level within limits in Delhi network during winter season.

DTL Agenda:-

2. Requirement of shutdown of 220 kV D/C Maharani Bagh to Trauma Centre Ckt for construction of proposed underpass of PWD at Mathura Road.

Project department requested for arranging the shutdown due to construction of proposed underpass of PWD at Mathura Road, DTL has to shift the existing 220 kV U/G laid cables immediately in order to facilitate PWD for making underpass.

For jointing the new cables with existing cables between JB-05 & JB-06, DTL (Project-II Deptt.) proposed the simultaneous shutdown required for both the circuitst as under:-

S. No	Name of Transmission line	Shutdown Period
1.	220 kV Maharani Bagh- Trauma Centre Ckt-I & -II	15.11.2021 to 01.12.2021

After deliberations, OCC approved the above shutdown for proposed dates. Project Lines/DTL shall ensure to complete the work within scheduled time.

(Action by DTL Project-II)

DMRC/DTL Agenda:-

3. Requirement of shutdowns for the work of raising the height of 220 kV D/C transmission line which are infringing Maujpur to Majlisark DMRC corridor phase- IV works.

DMRC requested for arranging the shutdown required for stringing of conductor, dismantling of existing conductor & tower etc as under:-

S.N.	Name of Transmission Line	Shutdown Period	Scope of Work
1.	220 kV Mandola – Goplalpur ckt-1. (Near Gujjar Chowk)	06.11.2021 to 07.11.2021 (02 days)	Stringing and final commissioning of 220 kV works.
	220 kV Mandola – Goplalpur ckt- 2. (Near Gujjar Chowk)	07.11.2021 to 07.11.2021 (01 day)	
2.	220 kV SOW – Gopalpur ckt-1 & 2. (Near Sonia Vihar)	09.11.2021 to 11.11.2021 (03 days)	As a safety measure for Monopole foundation work just beneath the 220 kV line.

After deliberations, the OCC approved above shutdowns and advised DMRC:-

(i) For timely revival of the circuits as per approved schedule.

(ii) To send the shutdown request to SLDC by 02.11.2021 for NRPC approval as applicable.

(Action by DMRC)

NCRTC/ DTL Agenda:-

4. Requirement of shutdowns on 220 kV D/C Maharani Bagh - Lodhi Road Lines.

NCRTC, with the permission of DTL, is modifying/ re-conductoring 220 kV T/L from Maharani Bagh to Lodhi Road. NCRTC, has planned to shift 220 kV line & required shutdowns forwarded by DTL O&M-II as under:-

S.no.	Name of Transmission Line	Shutdown Period
1.	220 kV Maharani Bagh-Lodhi Road Ckt-II	20.11.2021 to 21.11.2021
2.	220 kV Maharani Bagh-Lodhi Road Ckt-I	23.11.2021 to 24.11.2021

NCRTC informed that above shutdowns are required for stringing work from Tower No. 19, however DTL O&M-II stated that the work is required to be done from Tower No. 18 and as per In-Principal approval. NCRTC then stated that to complete the work as per approved plan, DTL needs to provide shutdown of both the circuits simultaneously.

After detailed deliberation among members of DTL, DISCOMs & SLDC, the OCC approved the shutdown of 220 kV Maharani Bagh - Lodhi Road Ckt- I & II (both Ckts) from 19.11.21 to 21.11.21 subject to following conditions:-

- 1). The shutdowns will be granted on real time basis keeping in view the system conditions prevailing at that time.
- 2). After getting clarification and approval of all necessary documents from DTL (Planning), NCRTC will submit the same to DTL O&M department before availing the shutdown.
- 3). SLDC along with NDMC & BRPL to prepare load management plan during this period, as Lodhi Road substation will be completely OFF for 03 days continuously.

OCC further advised NCRTC for timely revival of the circuits.

(Action by NCRTC/DTL(O&M-II), SLDC & DISCOMs)

On Table Agenda

NHAI/ DTL Agenda:-

1). Requirement of shutdowns for the work of shifting/raising of 220 kV HT lines of DTL located across the ROW of Dwarka Expressway (Package-II).

NHAI requested for arranging the below shutdowns forwarded by DTL/O&M required for implementing Dwarka Expressway from Dwarka sector-21 to Delhi/Haryana border.

S.no.	Name of Transmission Line	Shutdown Period
1.	220 kV Bamnauli-Dial Ckt-I	06.11.2021 to 15.11.2021
2.	220 kV Bamnauli-Dial Ckt-II	06.11.2021 to 25.11.2021

After detailed deliberation among members of DTL, DISCOMs & SLDC, OCC approved the shutdowns as per above schedule and requested SLDC to inform GMR (DIAL) also regarding the shutdown.

(Action by SLDC)

DTL Agenda:-

2). Issuance of PTW.

In OCC meeting held on 23.09.2021, a sub-committee was formed to resolve the issue of PTW during shutdown/breakdowns of 11kV, 33kV & 66kV feeders of DISCOMs.

It was informed that, an online meeting of this sub- committee was convened on 21.10.2021 and various issues in connection with issuance of PTW of outgoing feeders of distribution companies from DTL sub-stations were deliberated.

OCC advised the sub-committee to submit its report in next OCC meeting.

(Action by sub-committee)

The meeting ended with thanks to the Chair.
