

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

MINUTES OF EMERGENCY OCC MEETING DT. 15.09.2015

E.D.(Tech) O&M)-I, DTL, Chairman-Delhi OCC welcomed all the members of OCC and distinguished guests to the meeting.

List of participants is enclosed.

The point-wised deliberations made during the meeting are as below:

1. Shutdown of various 66kV and 33kV Line sections for HTLS re-conductoring on 220kV Bamnauli-Naraina Circuits.

DTL proposed shutdown on the following line sections for carrying HTLS re-conductoring work on 220kV Bamnauli-Naraina Ckts-I&II:

S. No.	Name of the Line sections	Concer- ned Entity	Time period of S/D	For carrying HTLS re- conductoring work between tower sections
1	66kV Punjabi Bagh, Delhi-Mehrauli Road Gurgaon Ckt-I&II	HVPNL	2 days on daily basis	T. No. 30-31 (Both 220kV BML-NRN Ckts-I&II)
2	66kV G-2 Ckts-I&II & 66kV G-6 Ckts-I&II. emanating from 220kV PPK-I S/Stn.	BRPL	2 days on daily basis	T. No. 53-54 (Both 220kV BML-NRN Ckts-I&II)
3	33kV Khyber Line Ckts-I&II of MES emanating from 220kV Naraina S/Stn.	MES	9 hours (1 day)	T. No. 92-93 (220kV BML-NRN Ckt-II)
4	33kV Khyber Line Ckts-I&II of MES emanating from 220kV Naraina S/Stn	MES	9 hours (1 day)	T. No. 95-96 (220kV BML-NRN Ckt-II)
5	33kV Khyber Line Ckts-I&II of MES emanating from 220kV Naraina S/Stn	MES	9 hours (1 day)	T. No. 97-98 (220kV BML-NRN Ckt-II)

Shutdowns have been deliberated and OCC advised DTL to avail the shutdowns of 33kV Khyber Line Ckts-I&II of MES for carrying HTLS re-conductoring work on 220kV Bamnauli – Naraina Ckt.-II subject to energization of 220kV Bamnauli-Naraina Ckt-I and availability of feed to MES from 66kV Ridge valley Substation of BRPL.

Regarding the shutdown proposed at S. No.1, HVPNL informed that they have already proposed the shutdown of said circuits from 19.09.15 to 28.09.15 in NRPC OCC meeting on the request of PWD Delhi. Accordingly, OCC advised DTL to take up with HVPNL SLDC for the approved date of S/D of the said circuits in NRPC.

Regarding the shutdown proposed at S. No. 2, BRPL informed the shutdown of the circuits is not feasible at present loading conditions. OCC advised DTL to take up with BRPL regarding the same after 15 days.

(Action by DTL)

2. Uninterrupted supply to IGI stadium complex (BYPL agenda) :

3rd India African forum summit is going to be held at IGI stadium complex from 26th to 29 Oct 2015. Prime ministers of 54 countries are invited for the summit making it very important and prestigious event for New Delhi.

The power supply to IGI stadium complex is through 33 KV IGI stadium grid of BYPL, which in turn receives power from 220 KV RPH (Bay no.-12) and IP Stn (Bay no. 29 & 33).

Multiple partial grid collapses happened during last 15 days (on Mandola-IP section) have affected the supply of IGI stadium, thus underlining an area of utmost concern.

Accordingly, BYPL requested to deliberate the remedial/alternate arrangements for ensuring uninterrupted supply at event venue.

The issue has been deliberated and members are of opinion that at I.P., there shall be a dedicated 220kV bus to 33kV I.G. Stadium Ckts and one 220kV bus to be fed from BTPS end and the second bus to be fed from Mandola end with Bus coupler in OFF position. Further, 220kV I.P.-RPH Double circuit shall remain on the same 220kV Bus at I.P.

OCC advised DTL and SLDC to explore all the possibilities for having two different sources of supply for feeding 33kV IGI stadium Substation for improving the reliability of power supply.

OCC further advised DTL and BYPL to ensure the following before the event:






- Letter to Delhi Police by DTL for security at 220kV I.P. Substation.
- 33kV IGI substation to be manned.
- All maintenance activities of 33kV Bay No.29&33 at IP substation and Bay No. 12 at RPH to be completed for ensuring healthiness of the bays.
- Grass cutting at I.P. substation to be carried out.

(Action by DTL, BYPL, SLDC)

3. Meeting ended with vote of thanks to the Chair.

Attendance sheet of Emergency OCC Meeting held on dt. 15.09.15 at 03:00 P.M. in the Conference Room, SLDC Building, Minto Road, New Delhi

S.No.	Name (Sh.)	Designation	Company	Mobile No.	e-mail Id.	Sign.
1.	H. Vyas	ED(Tech)			Chair	
2.	Chander Shekhar	APC	BDMPL	9871621001	xenomdl@rediffmail.com	
3.	Chander Shekhar	DGM(T)	DTL	9999533652	chander.shekhar@dtl.gov.in	
4.	Chander Shekhar	AGM(EEM)	BTPL	9650993817	chander.shekhar@btpl.com	
5.	Rajesh Jaiswal	Manager	DTL	9999533812	rajesh.jaiswal@dtl.gov.in	
6.	R.P. Aggarwal	D.G.M	BYPPL	9350130627	rp.aggarwal@byppl.com	
7.	Suresh Kumar	JE(E/M)	MES	8447146921	seectric@gmail.com	
8.	Mukesh Daohich	GM(SO)	BYPPL	9350261451	mukesh.daohich@relianceada.com	
9.	Darshan Singh	Mgr(T)	DTL/SLDC	9999533837	darshan.singh.dtl@gmail.com	
10.	P.K. Gupta	GM(M)	SCD/DTL	9999533626	psd@pvt2012@gmail.com	
11.	S. MOHARJ	DGM(T)	DTL	9999533655	SMARFORCED@GMAIL.COM	
12.	B. P. Singh	DGM(EHV) BSES	BSES	9313353018	bsj.p.singh@relianceada.com	
13.	Balram Singh	D.G.M EHV	BSES	9312666334	Balramyadav@relianceada.com	
14.						
15.	M.L. GARG	Xen	HVPL	9357198171	mlgarg@hvpl.com	
16.	Y.P. Verma	Manager (T) 220KV LINES	DTL	9999533657	manoj220kvlines@gmail.com	
17.	Subhash C Jha	AMUD	DTL	9999533944	scj2k2205@yahoo.co.in	
18.	Md. Shudab Ahmad	Manager	TPDDL	9212991957	mdshudab.ahmad@tpddl.com	
19.	R.S. MEENA	DGM(T)	DTL	9999533665	rsmeena@dtl.gov.in	

20.	Anil Kumar	Mgr(T)	DTL	9999533774	anilk.dtl@gmail.com	
21.	S. Sutrader	DGM(T)	DTL	9999533671	mgr.om@rediffmail.com	
22.	Susheel Gupta	Mgr(DSLDC)	DTL	9999533926	susheel-es@yatoos.co.in	
23.	Rajesh Kr. Behigolle	AM(T) OS	DTL	9999533866	Dr. Pachigolle@dtl.gov.in	
24.	S. K. Srinivasa	GM(S)	DTL	9999533640	srinivasa@juistf.com	
25.						
26.						
27.						
28.						
29.						
30.						
31.						
32.						
33.						
34.						
35.						
36.						
37.						
38.						
39.						
40.						