



DELHI TRANSCO LIMITED

(A Govt. of NCT of Delhi Undertaking)

Office of DGM(T)-OS

111, 1st Floor, 220 kV Sub-Stn Park Street Building,
New Delhi-110001

No. F.DTL/2021-22/DGM(OS)/ 115

Date: 18.08.2021

To,

All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM (DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee

Sub: Agenda for 5th Delhi OCC Meeting (2021-22) to be held on 24.08.2021 at 11:00 A.M. through video conferencing.

The 5th Delhi OCC meeting (2021-22) is scheduled to be held on dt.-**24.08.2021, 11:00 A.M** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,

(Hitesh Kumar)
DGM(T)-OS, DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 05/2021-22

Date : **24.08.2021**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 4th Delhi OCC meeting (2021-22) held on dated 27.07.2021.

The 4th Delhi OCC meeting (2021-22) was held on 27.07.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 22.07.2021. Minutes of the aforesaid OCC meeting were issued on 02.08.2021 and the same was also uploaded on the DTL website.

Following comments were received on circulated MOM:-

(a) Additional Agenda No-1:- Finalization of Critical/Essential load for existing Delhi Islanding Scheme.

As per MOM:- BYPL agreed to exclude 66 kV Wazirabad to Shastri Park Ckt.-1 & 2 and 66 kV Park Street to Shastri Park Ckt.-1 & 2 from the list of critical lines & provided consent to the list.

BRPL requested to consider the feeder list of island scheme according to their comments as above. Similarly TPDDL also requested to update the list as per their comments.

Further NDMC, MES and DMRC also gave their consent to the above listed load for finalization of Delhi island scheme.

OCC advised SLDC to incorporate the comment received from BRPL & TPDDL and update the final list accordingly & put up the updated list to the NRPC.

SLDC Comments:- Annexure-A of OCC additional agenda Sr.No.1 was compiled by the Protection Department of DTL and was further submitted to NRPC.

Delhi DISCOMs i.e. BRPL, BYPL and TPDDL have given their comments on Annexure-A circulated to OCC, which were deliberated in OCC meeting and finalized as per MoM of 4th OCC meeting held on 27.07.2021.

Since, the Annexure-A was compiled by the Protection Department of DTL as such necessary changes/comments suggested by BRPL, BYPL and TPDDL have to be incorporated by the Protection Department of DTL in the Annexure-A. The final Annexure-A has also to be submitted to NRPC by the Protection Department of DTL.

(Members may confirm)

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of September-2021.

DTL proposed planned shutdowns for the month of September-2021 (Annexure-I).

(OCC may deliberate)

3. Laying of 4 nos. 33kV NDMC Feeder cables in the existing duct at 220kV Trauma Center GIS.

A joint visit was convened with the officials of DTL & NDMC as per the direction of OCC meeting 28.06.2017 regarding pending works to be carried out by NDMC at 220kV HCML & Trauma Centre. As per the site MoM dated 06.07.2017, the NDMC had agreed to the points mentioned below:

1. Provide the cable holding arrangement with alignment to cable end termination in all feeders.
2. NDMC will ensure that all existing pipes were properly sealed from inside of the 33 kV GIS basement to avoid rain water entry in the basement and
3. Removal of excess loops of the 33kV cables left by NDMC.

It is also to mention here that NDMC agreed to execute above works as per MOM dt. 09.04.2015. DTL also has reminded NDMC vide DTL letter dated 18.04.2017 and 07.11.2019 for completion of above works. However, NDMC has not yet initiated to complete the above said work. Now NDMC intended to lay four nos. 33 kV Cables in the existing duct at 220 kV GIS substation Trauma center, whereas DTL has already informed in above cited letters that until the above arrangement and formalities were completed by the NDMC, the insertion of cables in the 33 kV GIS will not be allowed.

OCC is requested to kindly deliberate the matter and instruct NDMC for completion of above mentioned work before laying of other cables at 220 kV GIS substation Trauma center.

(OCC may deliberate)

4. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S.N	Element's Name	DISCOM /DTL	Date and Time of outage	Status of outage as on 16.08.2021
1.	220kV PPK -II - 66kV HASTAL CKT.-I	BRPL	23.06.2021	'B' PH. CABLE FAULTY
2.	220kV OKHLA - 33kV EAST OF KAILASH CKT.-I	BRPL	16.07.2021	'Y' PH. SINGLE CABLE FAULTY.
3.	220kV LODHI ROAD - 33kV NDSE CKT.	BRPL	13.08.2021	'Y' PH. SINGLE CABLE FAULTY

4.	220kV PPK -III - 66kV DMIDC CKT.-IV (BAY - 610)	BRPL	05.08.2021	'R' PH. SINGLE CABLE FAULTY
5.	220kV PPK-III - 66kV DMIDC RSF-1 CKT.-II	BRPL	08.08.2021	'Y' PH. SINGLE CABLE FAULTY.
6.	33kV JAHANGIRPURI - AZADPUR CKT.-II	TPDDL	20.07.2021	2ND CABLE FAULTY
7.	220kV GOPALPUR - 33kV MODEL TOWN CKT.-I	TPDDL	15.08.2021	2ND CABLE FAULTY
8.	220kV TRAUMA CENTRE-33kV STATE GUEST HOUSE CKT.	NDMC	22.06.2021	'Y' & 'B' PH. CABLE FAULTY
9.	33kV BAY - 16 (IP - NIRMAN BHAWAN)	NDMC	01.08.2021	'R' PH. CABLE FAULTY
10.	220kV PEERAGARHI - 33kV A-4 PASCHIM VIHAR CKT.	DTL	10.07.2021	'Y' PHASE SINGLE CABLE CONNECTOR FAULTY AT 220 kV PEERAGARHI S/S.
11.	220 kV NAJAFGARH :66kV CAPACITOR BANK -1,2 & 3	DTL	01.10.2020, 09.10.2020	SHUTDOWN FOR AUGMENTATION WORK.
12.	400kV BAWANA : 315MVA ICT-II	DTL	30.03.2021	315MVA ICT-II CAUGHT FIRE AND DAMAGED.
13.	AT SARITA VIHAR: - 220/66kV 100MVA PR.TR.-II	DTL	09.06.2021	TRIPPED ON DIFF, BUCHHOLZ RELAY. RISE IN GASES.
14.	AT PEERAGARHI: - 220/33kV 100MVA PR.TR.-I	DTL	10.07.2021	TRIPPED ON DIFF., TX FAULTY.
15.	220kV PARK STREET - PRAGATI CKT.-II	DTL	30.07.2021	CABLE FAULTY.
