



DELHI TRANSCO LIMITED
(A Govt. of NCT of Delhi Undertaking)
Office of DGM(T)-OS
111, 1st Floor, 220 kV Sub-Stn Park Street Building,
New Delhi-110001

No. F.DTL/2020-21/DGM(OS)/65

Date:17.02.2021

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM(DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee

Sub: Agenda for 10th Delhi OCC Meeting (2020-21) to be held on 19.02.2021 (Friday) at 11:00 A.M. through video conferencing.

The 10th Delhi OCC meeting (2020-21) is scheduled to be held on dt.- **19.02.2021 (Friday), 11:00 A.M.** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,

sd/-
(Hitesh Kumar)
DGM(T)- OS,DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 10/2020-21

Date : **19.02.2021**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 09th Delhi OCC meeting (2020-21) held on dated 27.01.2021.

The 09th Delhi OCC meeting (2020-21) was held on 27.01.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 21.01.2021. Minutes of the aforesaid OCC meeting were issued on 01.02.2021 and the same was also uploaded on the DTL website.

2. Proposed planned shutdowns of DTL for the month of March-2021.

DTL proposed planned shutdowns for the month of March-2021 (Annexure-I).

(OCC may deliberate)

3. Survival of Local Island at GTPS/ Pragati.

During the 20th GCC meeting as per MoM at S.No. 2.4 (9.12) following was discussed:-

“BYPL representative raised the issue of survival and subsequent synchronizing of local islanding at GT/ Pragati.

GCC advised DTL to carry out a joint visit with Discoms and IPGCL/ PPCL to analyze the requirements for sustaining Local Island at GT station”. -

The matter was deliberated in the 12th (2018-19) Delhi OCC meeting held on 28.03.2019 and a committee comprising of the following members was constituted for carrying out the above-desired work at Pragati:-

- (i) Sh. SatyendraPrakash, AGM(Elect./C&I), PPS-I, PPCL.
- (ii) Sh. B.L. Gujar, DGM (Prot.), DTL.
- (iii) Sh. Bharat Tiwari, MGR(OS), DTL
- (iv) Sh. Deepak Kumar, AM(T)-Pragati, DTL.

In the 9th OCC meeting dt:27.01.2021, DTL/Pragati & PPCL informed that the control wiring works as per finalized scheme has been completed and final testing is also done on 25.01.2021.

SLDC has requested PPCL/Pragati (DTL) to share all the documentation of finalized control scheme for testing (if required).

(Committee may update status)

4. Review of Delhi islanding Scheme

In 7th OCC dt: 25.12.2020, DTL Protection Deptt. informed that the revised Delhi Islanding scheme consists of Delhi local generation as well as generations from Dadri (Unit 1, 2), Dadri gas, and APCPL. At present, the generation from Dadri and APCPL are not being scheduled by DISCOMs. Hence, in the case of Island formation at 47.9Hz as per the approved scheme, there will be a deficient generation for the survival of the island. Thus all DISCOMs may be requested to review the scheduling else islanding of Delhi generators may be conceptualized so that in case of any grid disturbance essential load may be survived through islanding of Delhi generators. In this regard, DISCOMs and Generators under the Delhi Islanding scheme shall submit their comments to Delhi SLDC so that NRPC may be apprised. OCC also advised DISCOMs to submit the bifurcated details in the category of Essential, Critical & Supercritical loads as desired in NRPC OCC.

During the 8th OCC meeting dt: 29.12.2020, OCC deliberated on the matter based on submissions from BRPL, BYPL, and TPDDL for review in the existing islanding scheme of the Delhi network. DTL/Protection requested all Discoms to provide actual Critical/ Supercritical load being fed from DISCOM feeder with proper feeder name, name of actual critical/ Supercritical loads such as Hospital/Water treatment/ DMRC/ GMR/ VVIP areas and Name of DTL substation & DISCOM feeder from DTL end.

OCC advised that DISCOMs, DTL & Gencos under the Delhi Islanding scheme shall provide details/ submissions to SLDC for review/ finalization of the Islanding scheme.

BRPL, BYPL requested SLDC to share their current status on finalization of Delhi Islanding Scheme.

(BRPL, BYPL, TPDDL & SLDC may update status)

5. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S.N	Element's Name	DISCOM /DTL	Date and Time of outage	Status of outage as on 15.02.2021
1	220kV OKHLA - 33kV NEHRU PLACE CKT.-IV	BRPL	22.01.2021	'B' PH. SINGLE CABLE FAULTY.
2	33kV BAY -1 (IP - KILOKRI)	BRPL	29.01.2021	'R' PH. SINGLE CABLE FAULTY
3	220kV PEERAGARHI - 33kV MADIPUR CKT.	BRPL	02.02.2021	'Y' PH. SINGLE CABLE FAULTY.

4	400kV MUNDKA - 66kV NANGLOI CKT.	BRPL	07.02.2021	'R' PH. CABLE FAULTY
5	220kV WAZIRABAD - 66kV SONIA VIHAR CKT.-I	BYPL	06.02.2021	'R' PH. CABLE FAULTY
6	400kV HARSH VIHAR - 66kV NAND NAGARI CKT.-II	BYPL	09.02.2021	'R' PH. CABLE FAULTY
7	220 kV NAJAFGARH :66kV CAPACITOR BANK -1,2 & 3	DTL	01.10.2020, 09.10.2020	SHUTDOWN FOR Dismantling & Augmentation WORK. Expected by 28.02.2021
8	NARAINA : 16MVA PR.TR.-II	DTL	19.01.2021	SHUT DOWN FOR OVERHAULING OF TR. Expected by 21.02.2021
9	KANJHAWALA : 100MVA PR.TR.-I	DTL	29.01.2021	SHUT DOWN FOR COMPLETE OVERHAULING FOR ONE MONTH. Expected by 25.02.2021
10	ROHINI -I: 66kV BUS -I	DTL	04.02.2021	SHUT DOWN FOR REPLACEMENT OF ISOLATOR. Expected by 17.02.2021
11	BAMNAULI: 400kV BUS -II	DTL	01.02.2021	SHUT DOWN FOR RETROFITTING / 400kV ISOLATORS. Expected by 24.02.2021
12	AT PATPARGANJ: 20MVA PR.TR.	DTL	11.02.2021	SHUT DOWN FOR OVERHAULING OF TRANSFORMER. Expected by 28.02.2021
