



DELHI TRANSCO LIMITED
(A Govt. of NCT of Delhi Undertaking)
An ISO 9001:2015 certified company
Office of Mgr. (T) OS-II
IInd Floor, ERP centre, SLDC Minto Road,
New Delhi-110002
Website:-www.dtl.gov.in

No. F.DTL/2020-21/Mgr.(OS)-II/01

Date:26.05.2020

To,
All Members of Operation Co-ordination committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC &AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM(DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee

Sub: Agenda for 01st Delhi OCC Meeting (2020-21) to be held on 29.05.2020 (Friday) at 11:00 A.M. through video conferencing.

Dear sir/madam,

The 01st Delhi OCC meeting (2020-21) is scheduled to be held on dt.- **29.05.2020 (Friday), 11:00 A.M.** in the office of GM(O&M)-II, Delhi Transco Ltd., 220kV Sub-Stn Park Street, Opp. Talkatora Stadium, Near R.M.L. Hospital, New Delhi-110001. **This meeting will be conducted through video conferencing. The link for joining the meeting is attached in mail.**

Agenda enclosed, Members are hereby requested to make it convenient to attend the meeting via **video conferencing.**

Thanking You.

Yours Sincerely,

sd/-
(Sh. Anil Sharma)
Mgr.(T)- OS,DTL

DELHI TRANSCO LIMITED
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 01/2020-21

Date : **29.05.2020**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-II, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street,
Opp. Talkatora Stadium, Near R.M.L. Hospital,
New Delhi-110001

1. Confirmation of minutes of 11th Delhi OCC meeting (2019-20) held on dated 20.02.2020.

The 11th Delhi OCC meeting (2019-20) was held on 20.02.2020 in accordance with the agenda circulated vide letter dt: 18.02.2020. Minutes of the aforesaid OCC meeting were issued on 04.03.2020 and the same was also uploaded on DTL website.

2. DTL AGENDA:

2.1 Proposed planned shutdowns of O&M, DTL for the month of June-2020.

DTL O&M deptt. has proposed the planned shutdowns for the month of June-2020.

(OCC may deliberate)

3. BYPL AGENDA:

3.1. BYPL requesting to increase the tap positions of all PTR's at 220kV Level

As the load is now increasing day by day and voltage level is getting low, BYPL suggest to please increase the tap position of all the transformer's at 220KV substations

(OCC may deliberate)

3.2 Energization of 220KV Preet Vihar Circuits of BYPL.

Kindly charge the all 33KV circuits coming from 220KV Preet Vihar to BYPL Substations because at some substations alternate supply is only 220KV Preet Vihar and substation is running on single source e.g. 33KV Preet Vihar Grid.

(OCC may deliberate)

4. TPDDL AGENDA:

4.1. Meeting with SLDC

As mentioned at clause 4.2 of minutes of Delhi OCC meeting held on 28.08.2019, SLDC is to call monthly meeting under chairmanship of DGM (SO) with all DISCOMs to resolve system operation and energy account related issues. However, to unknown reasons, such meetings have not been held. OCC is requested to intervene in the matter and advise concerned officials to hold such meetings, regularly.

(OCC may deliberate)

4.2 Issues in VHF communication between Tata Power-DDL and SLDC Control Room

Since last few months, we have been struggling to establish effective communication with SLDC control room over VHF. Continuous rigorous efforts, including hardware replacement, have been made at our end for resolving the same. In furtherance, we had also sent our representative to visit SLDC control room to diagnose the root-cause of the issue. During the visit, it transpired and agreed upon by SLDC representative, Sh. ShardaRautare that the problem lies with the VHF receiver installed at SLDC end. DTL is, therefore, once again requested to arrange said rectification carried out at the earliest possible as owing to this a critical communication link between Tata Power-DDL and SLDC control room is out of service. Multiple correspondences have also been made in past in this regard.

(OCC may deliberate)

4.3 Installation of “LoRa (Long Range) Modems” on DTL Main Energy Meters

Presently, daily energy consumption details are being provided manually by DTL grid staff. This includes capturing meter reading of each and every exchange point and then manually feeding it into a web portal developed by Tata Power-DDL. Since the data is quite critical and significant in nature, manual interventions should be bring down to least possible level. In this spirit, DTL is requested to allow Tata Power-DDL to install “LoRa (Long Range) Modems” on DTL Main Energy Meters to fully automate the entire process and make it free from any manual intervention.

(OCC may deliberate)

5. Long/Recent Outage/Breakdown of Elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in Delhi Power system as under:

S.N	Element’s Name	Discom/ DTL	Date and Time of outage	Status of outage as on 26.05.2020
1.	66kV PARK STREET – RIDGE VALLEY CKT.-I	BRPL	01.06.2019	‘Y’ PH. CABLE FAULTY. BRPL informed that this cable is outlived and contains multiple faults in this cable. OCC advised BRPL to expedite to revive this faulty feeder. BRPL may update.

2.	33kV RIDGE VALLEY - KHEBAR LANE CKT.-II	BRPL	01.06.2019	'Y' PH. Single CABLE FAULTY. BRPL informed that the agenda related to handover this ckt to MES to be putup before Steering Committee. BRPL may update.
3.	66kV WAZIRABAD - YAMUNA VIHAR CKT.-II	BYPL	24.05.2020	'Y' & 'B' PH. CABLE FAULTY
4.	66kV MANGOLPURI -I - MANGOLPURI -II CKT.-I	TPDDL	22.05.2020	
5.	33kV WAZIRPUR -3 - SHAHZADA WALA BAGH CKT.	TPDDL	22.05.2020	SINGLE CABLE FAULTY
6.	315 MVA ICT-II at MUNDKA	DTL	29.09.2019	DUE TO FIRE, ICT BURNT. . Replacement under progress
7.	220kV PEERAGARHI - MUNDKA CKT.-II AT PEERAGARHI	DTL	25.02.2020	CABLE DAMAGED DUE TO SWITCHING FAULT OCCURRED AT SAME LOCATION OF CKT.-I
8.	SARITA VIHAR - 220/66kV 100MVA PR.TR.-I	DTL	20.01.2020	SHUT DOWN FOR DISMENTALING OF TR. WITH REPLACEMENT OF 160MVA PR.TR.
9.	220/66kV 160MVA PR.TR.-II AT R.K. PURAM	DTL	06.03.2020	TR. TRIPPED ON BUCHLO & DIFFERENTIAL RELAY DUE TO HIGH VALUE OF ACETYLENE GAS . TRANSFORMER TO BE REPAIRED
10.	220kV PRAGATI – Sarita Vihar Ckt	DTL	21.03.2020	SHUT DOWN FOR STRENGTHING OF ENDS.
11.	220kV BTPS - OKHLA CKT.-I&II	DMRC	22.05.2020	SHUT DOWN FOR DISMENTALING OF 4 NO. OLD TOWER AND ERRECTION OF 4 NO. MONOPOLE BY DMRC. EXPECTED BY 01.06.20.
12.	315MVA ICT-I AT 400kV BAWANA	DTL	24.05.2020	TAN DELTA HIGH OF HV SIDE 'B' PH. BUSHING. EXPECTED BY 27.05.2020.
13.	220kV PRAGATI -MAHARANI BAGH CKT.	DTL	23.05.2020	SHUT DOWN FOR COMMISSIONING OF 220kV D.C. DOUBLE RUN CABLE AT PRAGATI STN. EXPECTED BY 27.05.2020.
