



**DELHI TRANSCO LIMITED**  
(A Govt. of NCT of Delhi Undertaking)  
Office of DGM(T)-OS  
111, 1<sup>st</sup> Floor, 220 kV Sub-Stn Park Street Building,  
New Delhi-110001

No. F.DTL/2021-22/DGM(OS)/72

Date: 18.05.2021

To,

**All Members of Operation Co-ordination Committee**

<b>DTL</b>	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)
<b>SLDC</b>	ED (SLDC) DGM (SO)
<b>TPDDL</b>	HOD (PSC&AM) Sr. Manager (PSC)
<b>BRPL</b>	AVP (SO)
<b>BYPL</b>	AVP (SO)
<b>NDMC</b>	Superintending Engineer, E-1
<b>IPGCL</b>	AGM (T) Opr. GTPS
<b>PPCL</b>	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III
<b>MES</b>	AEE/M.SLDC Officer
<b>BBMB</b>	Sr. Executive Engineer, O&M
<b>DMRC</b>	Addl. GM (Elect.) Sr.DGM (Traction)
<b>GMR(DIAL)</b>	GM(DIAL) Special Invitee
<b>N. Railways</b>	Sr. DEE (TRD) Special Invitee

**Subject: Agenda for 2<sup>nd</sup> Delhi OCC Meeting (2021-22) to be held on 25.05.2021 (Tuesday) at 11:00 A.M. through video conferencing.**

The 2<sup>nd</sup> Delhi OCC meeting (2021-22) is scheduled to be held on dt.- **25.05.2021 (Tuesday), 11:00 A.M.** and will be conducted through video conferencing as per the attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,

**(Hitesh Kumar)**  
DGM(T)- OS, DTL

## **DELHI TRANSCO LIMITED**

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

### **AGENDA FOR DELHI OCC MEETING NO. 02/2021-22**

**Date** : **25.05.2021**  
**Time** : **11:00 AM**  
**Venue** : **Via Video conferencing**  
In O/o-GM(O&M)-I, Delhi Transco Ltd.,  
220 kV Sub-Stn Park Street Building, New Delhi-01

#### **1. Confirmation of minutes of 1<sup>st</sup> Delhi OCC meeting (2021-22) held on 26.04.2021.**

The 1<sup>st</sup> Delhi OCC meeting (2021-22) was held on 26.04.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 13.04.2021. Minutes of the meeting were issued on 28.04.2021 and also uploaded on DTL website <http://dtl.gov.in> under news and information tab.

#### **2. Proposed planned shutdowns of DTL for the month of June-2021.**

Shutdowns proposed for the month of June-2021 by DTL are attached as Annexure-I for deliberation.

**(OCC may deliberate)**

#### **3. URGENT Maintenance Slot Over Indian Railways Line Between Shakarpur (Mandawali) to Tilak Brij (India Railway Location: 2/27G-28G TO 2/29G-30G) for Carrying Out Emergent 220kV Line Maintenance Work.**

During routine patrolling on dt. 12<sup>th</sup> May 2021, it has been observed that the 220kV PPG-Geeta Colony Ckt-I passing over railway overhead line between tower number 369 and 370 is badly damaged. It has been seen that probably the load is flowing through Steel wire.

Owing to the critical condition of the overhead conductor, this Ckt made off to avoid any further damage / falling over the railway overhead line in the interest of DTL/ Delhi's electrical system till the maintenance block is arranged through railway officials. The said 220kV Geeta Colony-Patparganj Ckt-I has been switched off w.e.f. 12<sup>th</sup> May 2021, 17:00 Hrs.

A letter vide ref no. No. F.DTL/206/2021-22/DGM(T)O&M East/F-1/06 dt.13<sup>th</sup>May 2021 has been submitted in the office of Sh H K Sharma, Sr Divisional Electric Engineer (G). Copy of said letter also sent to e-mail ID i.e. [ctatrdelhidivision@gmail.com](mailto:ctatrdelhidivision@gmail.com).

Indian Railway may be requested to provide the Maintenance Block to attend the damaged conductor on URGENT BASIS.

**(OCC may deliberate)**

**4. Long/recent Outage/breakdown of elements in Delhi power system.**

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S.N	Element's Name	DISCOM /DTL	Date and Time of outage	Status of outage as on 17.05.2021
1.	220kV PPK -2 - 66kV HASTAL CKT.-I	BRPL	05.05.2021	'B' PH. SINGLE CABLE FAULTY.
2.	66kV PPG INDL. AREA - VIVEK VIHAR CKT.	BYPL	15.05.2021	'Y' PH. CABLE FAULTY.
3.	220kV SHALIMARBAGH - 33kV JAHANGIRPURI CKT.	TPDDL	01.03.2021	CABLE FAULTY.
4.	66kV ROHINI -I - PITAMPURA -II CKT.-I	TPDDL	15.03.2021	ALL PH. CABLE FAULTY.
5.	66kV DHEERPUR - JAHANGIRPURI CKT.-II	TPDDL	13.05.2021	'B' PH. CABLE FAULTY.
6.	33kV BAY - 28 (IP - CONNAUGHT PLACE)	NDMC	12.04.2021	'R' PH. CABLE FAULTY.
7.	220 kV NAJAFGARH :66kV CAPACITOR BANK -1,2 & 3	DTL	01.10.2020, 09.10.2020	SHUTDOWN FOR DISMANTLING & AUGMENTATION WORK.
8.	400kV BAWANA : 315MVA ICT-II	DTL	30.03.2021	400kV 'B' PH. BUSHING BLASTED AND 315MVA ICT-II CAUGHT FIRE AND DAMAGED.
9.	220kV PRAGATI – PARK STREET CKT.-II	DTL	16.04.2021	TRIPPED ON DIST. PROTECTION. CABLE DAMAGED.
10.	220kV GEETA COLONY – PPG CKT.-I	DTL	12.05.2021	CONDUCTOR DAMAGED OVER RAILWAY LINE. PERMISSION / MAINTENANCE BLOCK FOR REPAIR AWAITED FROM RAILWAY DEPARTMENT.
11.	220kV MEHRAULI – DIAL CKT.-I&II	DTL	15.05.2021	SHUT DOWN FOR CABLE JOINTING WORK.
12.	220kV M. BAGH-H.C. M. LANE CKT.-II	DTL	12.05.2021	SHUT DOWN FOR NCRTC WORK.

\*\*\*\*\*