



DELHI TRANSCO LIMITED

(A Govt. of NCT of Delhi Undertaking)
Office Of DGM(OS)
1st Floor, 220 kV Sub-Strn Park Street Building,
New Delhi-110001

No. F.DTL/201/2021-22/DGM(OS)/152

Date: 18-11-2021

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr. PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM (DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee


Sub: Agenda for 8th Delhi OCC Meeting (2021-22) to be held on 29.11.2021 at 11:00 A.M. through video conferencing.

The 8th Delhi OCC meeting (2021-22) is scheduled to be held on dt.- 29.11.2021, 11:00 A.M and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via video conferencing.

Thanking You.

Sincerely yours,


18/11/2021
Hitesh Kumar
DGM(T) OS, DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 08/2021-22

Date : 29.11.2021
Time : 11:00 AM
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 7th Delhi OCC meeting (2021-22) held on dated. 26.10.2021.

The 7th Delhi OCC meeting (2021-22) was held on 26.10.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 18.10.2021 & 29.10.2021. Minutes of the OCC meeting were issued on 01.10.2021 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of December-2021.

DTL proposed planned shutdowns for the month of December-2021 (Annexure-I).

(OCC may deliberate)

3. Issuance of PTW.

In OCC meeting held on 23.09.2021, A sub-committee was formed to resolve the issue of PTW during shutdown/breakdowns of 11kV, 33kV & 66kV feeders of DISCOMs.

During OCC meeting dt:26.10.2021, it was informed that an online meeting of this sub-committee was convened on 21.10.2021 and various issues in connection with issuance of PTW of outgoing feeders of distribution companies from DTL sub-stations were deliberated. OCC advised to submit the report in next OCC meeting.

The above sub-committee convened another meeting on 16.11.2021, the minutes of meeting reproduced as under:-

“Various prospective challenges, present practices and procedure in connection with issuance of PTW of outgoing feeders of Distribution companies from DTL sub stations were discussed and deliberated. Based on deliberations of the committee, it has been felt that the present procedure of availing shutdown from DTL sub stations may be continued.”

(OCC may deliberate)

4. Shutdowns requested by PGCIL for stringing of 400kV conductor for LILO of S/C 400 kV Bamnauli - Jhatikalan Transmission Line at 400 kV substation Dwarka.

DTL, O&M-I division forwarded the following shutdowns to consider discussing in OCC meeting is as under:-

SN.	Name of DTL Line	Shutdown Period	Tower Location
1	a) D/C Bamnauli-PPK-I Line b) D/C Dwarka-PPK-III Line	05.12.2021 to 07.12.2021 (03 days)	AP25-AP26 and AP 28-AP29
2	a) D/C Bamnauli – NJF Line b) D/C Bamnauli-PPK-I Line c) D/C Bamnauli-PPK-II Line	25.11.2021 to 26.11.2021 (02 days)	AP5-AP6
3	a) D/C Bamnauli-PPK-I b) D/C Bamnauli-PPK-III Line	01.12.2021 to 03.12.2021 (03 days)	AP14–AP15

(OCC may deliberate)

5. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 16.11.2021
1.	220kV PEERAGARHI - 33kV A-4 PASCHIM VIHAR CKT.	BRPL	10.07.21	'Y' PH. SINGLE CABLE CONNECTOR FAULTY.
2.	220kV OKHLA - 33kV EAST OF KAILASH CKT.	BRPL	25.08.21	'R' PH. SINGLE CABLE FAULTY.
3.	220kV OKHLA - 33kV NEHRU PLACE CKT.-I	BRPL	27.10.21	'B' PH. SINGLE CABLE FAULTY.
4.	220kV PPK-II - 66kV HASTAL CKT.-I	BRPL	18.10.21	'B' PH. SINGLE CABLE FAULTY.
5.	220kV NAJAFGARH - BODELLA -II CKT.-II	BRPL	15.11.21	'R' PH. SINGLE CABLE FAULTY.
6.	220kV NAJAFGARH - BODELLA -II CKT.-I	BRPL	15.11.21	'B' PH. SINGLE CABLE FAULTY.

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 16.11.2021
7.	220kV PATPARGANJ - 66kV VIVEK VIHAR CKT.-II	BYPL	10.11.21	'B' PH. CABLE FAULTY
8.	220kV DSIDC BAWANA - 66kV BAWANA -I CKT.-I	TPDDL	12.11.21	CABLE FAULTY
9.	33kV BAY - 16 (IP - NIRMAN BHAWAN)	NDMC	01.08.21	'R' PH. CABLE FAULTY
10.	33kV BAY -28 (IP-CONNAUGHT PLACE)	NDMC	17.10.21	'R' PH. CABLE FAULTY
11.	33kV PARK STREET - NIRMAN BHAWAN CKT.	NDMC	02.11.21	'R' & 'Y' PH. CABLE FAULTY
12.	400kV BAWANA, 315MVA ICT-II	DTL	30.03.21	315MVA ICT-II CAUGHT FIRE AND DAMAGED.
13.	AT PEERAGARHI: - 220/33kV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFFERENTIAL. TX FAULTY.
14.	220kV LODHI ROAD - 33kV DEFENCE COLONY CKT.	DTL	30.09.21	BREAKER PROBLEM.
15.	AT PPK -I : 20MVA PR.TR.-III	DTL	20.10.21	SHUT DOWN FOR OVER-HAULING OF TRANSFORMER.
16.	AT PPK -II : 220/66kV 100MVA PR.TR.-II	DTL	15.11.21	SHUT DOWN FOR OVER-HAULING OF CKT. BREAKER.
17.	220kV MAHARANI BAGH - TRAUMA CENTRE CKT.-I&II	DTL	15.11.21	SHUT DOWN FOR JOINTING WORK OF NEW CABLE BETWEEN J.N. -05 AND JB -06 FOR PWD WORKS.
18.	220kV BAMNAULI - DIAL CKT.-I & -II	DTL	09.11.21	SHUT DOWN FOR NHAI MONOPOLE ERECTION WORKS.
19.	220kV BTPS - OKHLA CKT.-II	DTL	15.11.21	SHUT DOWN FOR OVER-HAULING OF CKT. BREAKER.
20.	220kV PARK STREET - 66kV DMRC CKT.-I&-II	DTL	19.10.21	SHUT DOWN FOR GRID SHIFTING WORK AT DMRC END.
