

Ph.: 011-25683304

Email: dgmosdtl@gmail.com

दिल्ली ट्रांसको लिमिटेड
DELHI TRANSCO LIMITED
Office of DGM (OS & Lines)
Convener (Operation Co-ordination Committee)
Room No. 10, 1st floor, 220KV S/ Stn. Bldg.,
Naraina, Ring Road, New Delhi-110010

No. F.DTL/831/F.4/2014-15/DGM (OS & Lines)/46

Date: 11.06.2014

To: **Members of Operation Co-ordination committee**

DTL	General Manager (O&M)-I Chairman OCC General Manager (O&M)-II GM (Planning) DGM (O&M)-I, II & III DGM(400kV) DGM (M/P) DGM(Plg.)	Fax no. 011-23366160 Fax No.011-23622707 Fax no. 011-23366160 Fax No.011-23632031
SLDC	General Manager (SLDC) DGM (SO)	Fax no. 011-23221069 Fax no. 011-23221059, 23221012
TPDDL	HOD (PSC &AM) Sr. Manager (PSC)	Fax no. 011-66050602 Fax no. 011-66050602
BRPL	Asstt. Vice President (SO)	Fax no. 011-39996549
BYPL	Dy. General Manager (SO)	Fax no. 011-39996549
NDMC	Superintending Engineer	Fax no. 011-23235754
IPGCL	DGM (I/C) RPH DGM (O) GTPS	
PPCL	DGM (O) PPCL	
MES	AEE/M.SLDC Officer	
BTPS	AGM (EEMG)	Fax no. 011-26944348
BBMB	Sr. Executive Engineer, O&M	Fax no. 011-28315542,
GT	GM (T) DGM (E)	e-mail: rkkapoor57@gmail.com e-mail: adkjha84@gmail.com
DMRC	DGM(Elect.)	

विषय: प्रचालन समन्वय उपसमिति आपात बैठक दिनांकित 11.06.2014 (बुधवार) शाम 04:00 बजे का कार्यवृत्त ।

Sub: MOM of Emergency OCC Meeting dated 11.06.2014 (Wednesday) at 04:00 PM

प्रचालन समन्वय उपसमिति की आपात बैठक दिनांकित दिनांकित 11.06.2014 (बुधवार) शाम 04:00 , प्रथम मंजिल, सम्मेलन कक्ष, एस एल डी सी भवन, मिंटो रोड, नई दिल्ली में आयोजित की गई। उक्त बैठक के कार्यवृत्त की एक प्रति सूचनार्थ व आवश्यक कार्यवाही हेतु इस पत्र के साथ संलग्न है।

The Emergency OCC meeting was held on dt. 11.06.2014 (Wednesday) at 04:00 PM in the Conference Room, 1st Floor, SLDC Building, Minto Road, New Delhi. A copy of the minutes of meeting is enclosed herewith for favour of information and necessary action.

Sd/-
(लवलीन सिंह)
(Loveleen Singh)
उपमहाप्रबंधक (प्रचालन सेवाएं एवं लाइन्स)
Dy.General Manager (Operation Services & Lines)
संयोजक, प्रचालन समन्वय उपसमिति
Convener, Operation Coordination Committee

Enclosure:

प्रचालन समन्वय उपसमिति बैठक दिनांकित 11.06.2014 का कार्यवृत्त ।
MOM of OCC meeting dt.11.06.2014

DELHI TRANSCO LIMITED
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)
Office of Dy. Gen. Mgr. (OS & Lines)
220KV S/Stn. Bldg. Naraina, New Delhi-110010
Tele: 25683304

MINUTES OF EMERGENCY OCC MEETING DT. 11.06.2014

GM (O&M)-I, DTL, Chairman-Delhi OCC welcome the members and distinguished guests to the meeting. DGM (OS&L), DTL – Convener Delhi OCC informed that emergency OCC meeting has been called on to discuss emergency shut-down proposed by M/S PGCIL on 400/220 kV, 315 MVA ICT at Mandola S/Stn. (PGCIL) as per mandate given by MOP for energization of ICT within two days.

1. Shutdown of 400/220kV 315MVA ICT-1 at 400kV Mandola S/Stn.

M/s PGCIL proposed shutdown of 400/220kV 315MVA ICT-1 at 400kV Mandola S/Stn. for 5 hrs. for 2 days to carry out jumpering and charging of one spare 315MVA ICT as per direction of MoP, Govt. of India to reduce the overloading of other four ICTs at Mandola. With charging of the ICT, the transformation capacity shall be increased by about 250MW. To chalk out the modality and timing of shutdown, an emergency meeting of Delhi OCC has been convened on 11.06.2014 at SLDC building at 4:00 P.M.

Delhi OCC deliberated the modalities of shutdown with BYPL, TPDDL and DMRC and generating stations of Delhi. After deliberation, it was decided to allow the shutdown on dt. 12/06/2014 and 13/06/2014 during off peak hours i.e. 04:00Hrs to 09:00Hrs. Since, the substantial load shedding has been occurring in East Delhi area in almost all parts of the day since 07.06.14 due to outage of 220kV BTPS – Noida – Gazipur Circuits which normally caters 180MW of load. As such, it was decided not to carry out any additional load shedding in East Delhi area owing to the shutdown and TPDDL would have to shed in case of need arises, as the load of the existing three ICTs at Mandola would be restricted to 750MW during the shutdown period. DMRC informed that they will shift their load of around 10MW from 220kV Kashmere Gate to 220kV Rohini S/Stn. which would result in reduction of Mandola's ICT loading and increase the Bawana loading.

TPDDL representative requested OCC to provide 66kV Bus at 220kV Narela so that they can back-charge the bus through 66kV Rohini-2 to provide supply to Narela town-ship. DTL and SLDC assured to provide the same at Narela so that load shedding can be minimized. Further, TPDDL also requested OCC to provide margin at 220kV Bawana – DSIIDC Bawana – Narela double circuit link to meet the load of feeding areas from 220kV Narela. SLDC informed that the same shall be provided subject to real time loading conditions.

It was also informed that to enhance the generation at load center to ease the loading on Mandola ICTs and 220kV Maharaniabagh – SaritaVihar – Pragati Circuits, certain quantum of gas has been diverted from CCGT Bawana to IPGCL's GT resulting into the

enhancement of 45MW at GT station making its total generation of 172 MW during the peak load hours. OCC also noted that due to the enhancement of generation at local stations, Delhi could meet the maximum demand of 5470MW today at 14:45 Hrs despite the fact of outage of major 220kV lines mainly 220kV Maharaniabagh – Trauma Center double circuit line and 220kV BTPS – Noida – Gazipur single circuit.

As such, it was decided to allow shutdown on dt. 12/06/2014 and 13/06/2014 during off peak hours i.e. 04:00Hrs to 09:00Hrs. SLDC shall manage the load to the extent possible to avoid load shedding.

(Action by SLDC/TPDDL/ /DTL)

2. Frequent trippings at BTPS.

Representative of BTPS informed that in the recent past, tripping of 220kV lines from BTPS has increased. In the month of April, May and June 2014, there were 12, 31 and 7 nos. of trippings respectively. It was informed that rampant unauthorized constructions beneath the Mehrauli line causing the tripping when the load increases during the day peak. Some demolition work has already been carried out and notices have also been served to the residents of unauthorized constructions. As far as Okhla lines are concerned, Lines maintenance division of the DTL has informed that they would carry out the necessary remedial works like trimming of trees etc. to avoid the trippings. BTPS was advised to take up with concerned agency to reduce trippings on 220kV Alwar and Noida lines.

(Action by DTL)

3. Swapping of gas from CCGT Bawana to TPDDL's Rithala Generating Station.

At present, TPDDL's Rithala generating station is unable to generate power due to non-availability of APM gas. Govt. of India has provided gas to enhance the generation at CCGT Bawana. Since, the evacuation of generation of CCGT Bawana is at 400kV level, Delhi is not getting benefited from its generation as far as tackling the problem of transmission constraints. If the same gas is provided to TPDDL's Rithala generating station, transmission constraints of North and North - West Delhi can be resolved upto certain extent.

TPDDL was requested to take up the matter with the concerned agencies for getting the gas allocated to it as it was informed that all units are in healthy condition at the generating station.

(Action by TPDDL)

Meeting ended with vote of thanks to the Chair.

Attendance sheet for Emergency OCC meeting dtd. 11.06.14 at 04:00 P.M. in the Conference Room, 1st Floor, SLDC Building, Minto Road, New Delhi.

S. No.	Name (Sh.)	Des.	Organization	Mobile No.	E-mail Id	Signature
1	Pran Prakash	GM (O&M) - I	DTL	999533630	Chair	
2	Dhruv Singh	DM (SO)	DTL	999533659	dmso@prail.com	
3	Mukesh Dalwadi	GM (SO)	BJPL	9350261451	mukesh.dalwadi@bjpl.com	
4	Ranjit Kumar Sharma	SSE	B&MB	9911140473	rajankumar@bjpl.com	
5	Mehendra Pal	Manager (SO)	DTL	9999533843	mehendra.pal@bjpl.com	
6	R.S. Meena	GM (O) Under	DTL	999533665	rsmeena@bjpl.com	
7	Kumar Viram	Asst. Mgr	TPDDL	9919686611	kumar.viram@tppower-dtl.com	
8	V.S. Shukla Shrivastava	AGM	TPDDL	9917991957	vshukla@tpddl.com	
9	Karnam Venm	AGM	TPDDL	9931152897	karnam.venm@tpddl.com	
10	S.S. Maheshwari	AGM	BTPS	9650993817	ssmaheshwari1954@gmail.com	
11	Pavan Kumar	AM/SLC	PRC	9910226580	pavan.p233@gmail.com	
12	M.C. Khosla	Manager/DTL	DTL	9810530486	mcc@bjpl.com	
13	Darshan Singh	Manager (D)	DTL	9999533837	darshan.singh@bjpl.com	
14	Harekumar Yadav	GM (SO)	DTL	9999533631	harekumar.yadav@bjpl.com	
15	Karnal Singh	DTL (SO)	DTL	9717269482	karnal.singh@bjpl.com	
16	C.P. Kishor	DTL (SO)	DTL	9999533644	cpk@bjpl.com	
17	V.VENUGOPAL	DTL (SO)	DTL	9871093902	vvenugopal@bjpl.com	
18	Sangeet Kumar	AM (SO)	SLDC	9999533917	sangeetkumar@sldc.com	
19	P.K.J. Gupta	GM (SO)	SLDC			
20	Rajesh Kr. Pathyalla	AM (O) - OS	DTL	9999533866	rk.pathyalla@dtl.gov.in	