

**DELHI TRANSCO LIMITED**  
(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

**MINUTES OF EMERGENCY OCC MEETING DT. 07.03.2016**

GM (O&M)-I, DTL, Chairman-OCC welcomed the members of OCC and other distinguished guests.

List of participants are enclosed here with.

The point-wise deliberations made during the Emergency OCC meeting are as below:

**1.0 Proposed shutdown on 220kV M.Bagh – Gazipur double circuit by PWD.**

Delhi PWD proposed shutdown on 220kV Maharani Bagh to Gazipur Double circuit of DTL for extension of Barapullah Elevated Road (Phase-III) from Sari Kale Khan to Mayur Vihar. PWD proposed the shutdown from 01.03.16 to 15.06.16 to complete the foundation work of pier P4 of the extradosed bridge.

OCC deliberated the proposed shutdown of PWD and approved the shutdown from 10.03.16 to 25.04.16 subject to the following conditions:

- In case of emergency, PWD shall clear all their activities at site for the energization of the double circuit within two hours. (The nodal officer from PWD is “Sh. P.C. Chanana, Project Manager, Mobile No.9873337001”)
- If any additional generation is required due to line constraints, then the incremental cost of generation from PPCL/IPGCL will be borne by PWD as DISCOMs have not agreed to bear the cost of incremental generation. Though exact cost of generation cannot be worked out now, however the tentative cost may be around Rupees 10 crores as it will depend upon real time conditions.
- In case of load constraints where additional generation is required from PPCL/IPGCL to meet the load, the shutdown (PTW) on the said circuits will be cleared if PWD do not agree for the payment of incremental cost of generation to PPCL/IPGCL.

DTL suggested PWD to have all safety arrangements while carrying out the said work below the transmission line. PWD shall also explore the possibility of arranging safety net/earth guard below the transmission line to reduce the shutdown period. SLDC will work out the extra generation required during the said shutdown period.

IPGCL/PPCL informed that they require advance amount payment from PWD in case of requirement of additional generation during the aforesaid period.

**(Action by PWD, SLDC, BYPL)**

**2.0 Proposed shutdown of STG units of PPS III Bawana CCGT.**

PPCL proposed the shutdown of STG-I & II from 28.03.16 to 14.04.16 to attend CW channel work. During the shutdown period, generation at CCGT Bawana shall be available on open cycle @ Rs. 4.67 per unit approximately.

OCC deliberated the proposed shutdown by PPCL and approved the same from 28.03.16 to 10.04.16.

However, DISCOMs i.e. BRPL, BYPL, NDMC and TPDDL informed that they do not require any generation from Bawana CCGT during the said shutdown as the cost of generation in open cycle is very high. In this regard, OCC advised all DISCOMs to arrange power from other utilities during the said shutdown period.

Further, OCC advised SLDC to inform the DISCOMs regarding actual date of availing shutdown by PPCL in one day advance (not less than 24 hours).

**(Action by PPCL Bawana, DISCOMs, SLDC)**

**3.0 Proposed shutdown on Unit No. 6 by GT.**

GTPS proposed shutdown on GT Unit No. VI from 01.04.2016 to 25.04.2016 for overhauling.

The shutdown has been deliberated and OCC approved the same.

**(Action by GTPS)**

**4.0 Meeting ended with vote of thanks to the Chair.**

Attendance sheet of Emergency OCC Meeting held on dt. 07.03.16 (Monday) at 03:00 P.M. in the Office of GM(O&M)-I, 220kV Substation building, Park Street, New Delhi

S.No.	Name (Sh.)	Designation	Company	Mobile No.	e-mail Id.	Sign.
1.	Boendra Prasad	GM(O&M) I	DTL		Chair	
2.	Md. Shadab Ahmad	Manager	TPDDL	9777991957	mdshadab.ahmad@tpddl.co.in	Shadab
3.	Hitesh Kumar	DGM(SO)	DTL	9999533662	hiteshkumar.afl@gmail.com	Hitesh
4.	S. Sureshkar	DGM(PLG)	DTL	9555533671	sgmplanning@gmail.com	Suresh
5.	Darshan Singh	mgr(T) SO	DTL/SLDC	9888533832	darshan.singh-dtl@gmail.com	Darshan
6.	S. K. Singh	DGM(SO)	DTL/SLDC	9999533673	simha.singh@yaho.com	S.K. Singh
7.	Mukesh Dadhich	GM(SO)	BYPL	9351261451	mukesh.dadhich@reliance.co.in	Mukesh
8.	AMIT MUDGAL	Manager	BRPL	8010930106	amit.mudgal@reliance.co.in	Amit
9.	V. Venkhopal	GM(PL)	DTL	987013902	venkhopal1960@yahoo.co.in	V. Venkhopal
10.	SATYA SUDHARAO . G	MAN(SO)	DTL	9999533877	msg-dtl@ymail.com	Satya
11.	P. K. PARMAR	CPM	PWD	9810544569	cpk.pwd.dtl@ymail.com	P. K. Parmar
12.	P. C. CHANDANA	DM P-2	PWD	9813335701	eeplod@ymail.com	P. C. Chandana
13.	Suresh Mohan	DGM(PM)	DTL	9999533655	smohan@ymail.com	Suresh
14.	K. S. MEENA	XEN(MIF)	NDSTC	9811203020	meenas21@rediffmail.com	K. S. Meena
15.	Rajesh K. Pachyolle	AM(T)-05	DTL	9999533866	R.K.Pachyolla@dtl.gov.in	Rajesh
16.						
17.						
18.						
19.						