



DELHI TRANSCO LIMITED
(A Govt. of NCT of Delhi Undertaking)
Office of DGM(T)-OS
111, 1st Floor, 220 kV Sub-Stn Park Street Building,
New Delhi-110001

No. F.DTL/2021-22/DGM(OS)/ 07

Date:13.04.2021

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM(DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee

Sub: Agenda for 1st Delhi OCC Meeting (2021-22) to be held on 19.04.2021 (Monday) at 11:00 A.M. through video conferencing.

The 1st Delhi OCC meeting of 2021-22 is scheduled to be held on dt.- **19.04.2021 (Monday), 11:00 A.M.** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,

sd/-
(Hitesh Kumar)
DGM(T)- OS,DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 01/2021-22

Date : **19.04.2021**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 11th Delhi OCC meeting (2020-21) held on dated 17.03.2021.

The 11th Delhi OCC meeting (2020-21) was held on 17.03.2021 through video conferencing in accordance with the agenda circulated vide letter dt: 12.03.2021. Minutes of the aforesaid OCC meeting were issued on 22.03.2021 and the same was also uploaded on the DTL website.

DTL Agenda:

2.1 Proposed planned shutdowns of DTL for the month of May-2021.

DTL proposed planned shutdowns for the month of May-2021 (Annexure-I).

(OCC may deliberate)

2.2 Requirement of shutdown by NCRTC on 220kV Transmission Line from Maharani Bagh to Sarita Vihar and Pragati to Sarita Vihar.

In 11th Delhi OCC meeting dt:17.03.2021, subjected shutdowns were discussed and approved from 01.04.2021 to 12.04.2021 with one of the conditions is that “*During shutdown of M.Bagh to Lodhi road 220 kV cks I & II, one Ckt of 220 kV M. Bagh-Lodhi Road must be charged on ERS & maintain the continuous supply to 220 kV Lodhi Road. The arrangement of ERS shall be made by NCRTC. NCRTC also assure both cks will be restored within 02 hours in case of any exigency*”. The shutdowns of Maharani Bagh to Lodhi road was approved for 03.04.2021 to 08.04.2021.

NCRTC informed that, the all approved shutdowns could not be availed due to non-availability of ERS.

Now NCRTC vide letter dated:05.04.2021 addressed to GM (O&M)-I/ Chairman (OCC), intimated that due to unavailability of ERS structure “*as a back up arrangement NCRTC have*

sought the opinion of the expert and there is a technique available for stringing/ destringing of the conductor without taking the shutdown of 220 kV circuit No-1 and No-2 of Maharani Bagh – Lodhi road Line. This technique is called **HOTLINE TECHNIQUE**.

To perform this work NCRTC requested to allow the below shutdowns:

SN	Transmission Line	Shutdown Period
1	220kV Maharani Bagh to Sarita Vihar Ckt	22.04.21 to 28.04.21.
2	220kV Pragati/IP Extension to Sarita Vihar Ckt	29.04.21 to 05.05.21

(OCC may deliberate)

3. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S.N	Element's Name	DISCOM /DTL	Date and Time of outage	Status of outage as on 12.04.2021
1.	33kV LODHI ROAD - NEHRU STADIUM CKT.	BRPL	08.04.2021	CABLE END BOX FAULTY
2.	66kV PPK -III - PASCHIM VIHAR CKT.	BRPL	02.04.2021	'B' PH. SINGLE CABLE FAULTY
3.	33kV JAHANGIRPURI CKT - 220 kV S/S SHALIMAR BAGH	TPDDL	01.03.2021	CABLE FAULTY
4.	66kV ROHINI -I - PITAMPURA -II CKT.-I	TPDDL	15.03.2021	ALL PH. CABLE FAULTY
5.	66kV DHEERPUR - JAHANGIRPURI CKT.-I	TPDDL	04.04.2021	'R'PH. CABLE FAULTY
6.	66kV REWARI LINE CKT - 220kV S/S PPK-I	TPDDL	06.04.2021	'R'PH. CABLE FAULTY
7.	33kV BAY - 16 (IP - NIRMAN BHAWAN)	NDMC	25.03.2021	'R' & 'B' PH. CABLE FAULTY
8.	220 kV NAJAFGARH S/S: 66kV CAPACITOR BANK -1,2 and 3	DTL	01.10.2020, 09.10.2020	SHUTDOWN FOR AUGMENTATION WORK.
9.	400kV BAWANA : 315MVA ICT-II	DTL	30.03.2021	315MVA ICT-II CAUGHT FIRE AND DAMAGED.

10.	AT MEHRAULI: 100MVA PR.TR.-I	DTL	25.02.2021	SHUTDOWN FOR OVERHAULING OF TR.
11.	AT MASJID MOTH: - 100MVA PR.TR.-I	DTL	19.03.2021	SHUTDOWN FOR OVERHAULING OF TR.
12.	AT S.O.WAZIRABAD: - 20MVA PR.TR.-IV	DTL	30.03.2021	MADE OFF DUE TO HIGH HYDROGEN GAS LEVEL.
13.	AT S.O. WAZIRABAD : - 220kV BUS COUPLER	DTL	07.04.2021	SHUT DOWN FOR REPLACEMENT OF CKT. BREAKER.
14.	AT NAJAFGARH: - 220/66kV 100MVA PR.TR.-IV	DTL	08.04.2021	SHUT DOWN FOR RELAY REPLACEMENT WORK AND OLTC OVERHAULING.
