



DELHI TRANSCO LIMITED
(A Govt. of NCT of Delhi Undertaking)
An ISO 9001:2015 certified company
Office of Mgr. (T) OS-II
IInd Floor, ERP centre, SLDC Minto Road,
New Delhi-110002
Website:-www.dtl.gov.in

No. F.DTL/2019-20/Mgr.(OS)-II/20

Date:26.08.2019

To,
All Members of Operation Co-ordination committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Plg.)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC &AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.)	
GMR(DIAL)	GM(DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee

Sub: Agenda for 5th Delhi OCC Meeting (2019-20) to be held on 28.08.2019 (Wednesday) at 2:30 P.M.

Dear sir/madam,

The 5th Delhi OCC meeting (2019-20) is scheduled to be held on dt.- **28.08.2019 (Wednesday), 2:30 P.M.** in the office of **GM(O&M)-II, Delhi Transco Ltd., 220kV Sub-Stn Park Street, Opp. Talkatora Stadium, Near R.M.L. Hospital, New Delhi-110001**

Agenda enclosed, Members are hereby requested to make it convenient to attend the meeting.

Thanking You.

Yours Sincerely,

sd/-
(Dr. Rajesh Kumar Arora)
Mgr.(T)- OS,DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 05/2019-20

Date : 28.08.2019
Time : 2:30 PM
**Venue : O/o-GM(O&M)-II, Delhi Transco Ltd.,
220 kV Sub-Stn Park Street,
Opp. Talkatora Stadium, Near R.M.L. Hospital,
New Delhi-110001**

1. Confirmation of minutes of 4th Delhi OCC meeting (2019-20) held on dated 29.07.2019.

The 4th Delhi OCC meeting (2019-20) was held on 29.07.2019 in accordance with the agenda circulated vide letter dt: 24.07.2019. Minutes of the aforesaid OCC meeting were issued and the same was also uploaded on DTL website.

Members may like to confirm the same.

2. DTL AGENDA:

2.1 Proposed planned shutdowns of O&M, DTL for the month of September 2019.

DTL O&M deptt. has proposed the planned shutdowns for the month of September-2019.

(OCC may deliberate)

3. SLDC Agenda

3.1 Implementation of Automatic Demand Management Scheme by Discoms.

Refer S.No. 2.2 of 20th GCC MoM wherein NDMC had informed that their software for ADMS has been upgraded and under testing and work is linked with the IPDS project, for which efforts shall be made to complete at the earliest. In last OCC meeting, NDMC has informed that the works of ADMS are in progress & expected to be successfully completed by September-2019.

In 162nd NRPC OCC meeting, MS, NRPC has requested from Delhi to give a presentation by Delhi Discoms on implementation of ADMS in forthcoming NRPC OCC meeting.

(OCC may deliberate)

3.2 Survival of Local Island at GTPS/ Pragati.

During 20th GCC meeting as per MoM at S.No. 2.4 (9.12) following was discussed:-

“BYPL representative raised the issue of survival and subsequent synchronizing of local islanding at GT/ Pragati.

GCC advised DTL to carry out a joint visit with Discoms and IPGCL/ PPCL to analyse the requirements for sustaining Local Island at GT station”.

The matter was deliberated in the 12th (2018-19) Delhi OCC meeting held on 28.03.2019 and a committee comprising of following members was constituted for carrying out the above desired work at Pragati:-

- (i) Sh. Satyendra Prakash, AGM(Elect./C&I), PPS-I, PPCL
- (ii) Sh. Hitesh Kumar, DGM(OS), DTL
- (iii) Sh. B.L. Gujar, DGM (Prot.), DTL
- (iv) Sh. Deepak Kumar, AM(T)-Pragati, DTL

In last OCC meeting, it was decided to visit the site on 20.08.19. it was requested to submit the findings in next OCC meeting for successful survival of Local Island at GTPS / Pragati.

The committee shall update their findings for successful survival of Local Island at GTPS / Pragati.

(Committee may update)

3.3 Information required by FOLD:

- a) Delhi has total generating capacity of 2024 MW in which 1972 MW is Gas Based Plants and 52MW is waste to Energy Plants. However data pertaining to solar/rooftop generation is not available to SLDC Delhi which may help in more informed forecasting and planning.

TPDDL & BYPL have already submitted the desired data.

The details from BRPL, NDMC & MES has not received till date.

In addition to above , it is noticed that the Solar Generation (actual) details in MUs from DIAL is always received late and this causes unavailability of Dial solar generation (MUs) in format 29 which needs to submit before 15th of each month to NRPC.

Dial is requested to submit the solar generation in MUs of previous month by 10th day of each current month to SLDC.

(DIAL, BRPL, NDMC & MES may update)

- b) In recent 29th FOLD Meeting held on 14.05.2019; it was suggested that all SLDC should have data regarding type of load and its characteristics. It was also advised to all SLDC's to segregate its load i.e. residential, commercial and industrial as it may help in forecasting demand.

All Discoms were requested to give segregated data of load and its characteristics in their operational areas to SLDC Delhi.

SLDC has not received any information from any of the discoms since May-2019.

(OCC may deliberate)

4. TPDDL Agenda

4.1 Load Reduction at Rewari Line Grid

In this summer season, Sagarpur CKT, which is usually used as I/C, changed to O/G to draw the load from Pappan Kalan through Rewari line Grid. Mayapuri CKT, which remains at No Load, is now drawing load from Rewari Line Grid. TPDDL has single source at Naraina, and it is not reliable in peak summer due to frequent tripping. Considering this, In next summer, TPDDL will not be in a position to provide the load to BRPL's Vishal, Mayapuri & Sagarpur Grid Feeders from Rewari Line grid.

BRPL is requested to ensure that load is removed from there before that. Status of A-43 Grid may also be updated.

(TPDDL may deliberate)

4.2 Meeting with SLDC

It has been decided that every month a meeting would be scheduled to resolve internal challenges and issues of DISCOMs. Please update the status.

DTL is requested to share the plan / status of upcoming PTR's at various 220 Grids, which pertains to TPDDL.

(TPDDL & SLDC may deliberate)

4.3 Breaker status of DTL Grids to DISCOMs

In OCC meeting, held in March 2019, TPDDL requested to get status of DTL breakers under ICCP-2 to get fast information about any tripping so that necessary resources may be deployed by them. This point was discussed earlier also but it has become even more important now considering PA guidelines. Please update the status.

(TPDDL may deliberate)

5. Long/Recent Outage/Breakdown of Elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in Delhi Power system as under:

S.N	Element's Name	Discom/ DTL	Date and Time of outage	Status of outage as on 23.08.2019
1.	66kV PARK STREET - RIDGE VALLEY CKT.-I	BRPL	01.06.2019	'Y' PH. CABLE FAULTY
2.	33kV OKHLA (220KV) - MASJID MOTH CKT.	BRPL	16.08.2019	UNDER BREAK-DOWN
3.	33kV BAY-1 (IP - KILOKARI)	BRPL	21.08.2019	'R' PHASE SINGLE CABLE FAULTY
4.	33kV OKHLA (220KV) - OLHLA PHASE-II CKT-II	BRPL	21.08.2019	'R' PHASE SINGLE CABLE FAULTY

5.	66kV MUNDKA - NANGLOI CKT.	BRPL	03.02.2019	'Y' PH. CABLE FAULTY
6.	66kV NANGLOI-MANGOLPURI-T-OFF MUNDKA CKT.	BRPL	09.08.2019	UNDER SHUT DOWN
7.	66kV MUNDKA- NANGLOI WATER WORKS CKT.	BRPL	13.08.2019	'R' PH. CABLE FAULTY.
8.	66kV PASHIM VIHAR - BODELLA-I CKT-I	BRPL	21.08.2019	UNDER SHUT DOWN
9.	33kV SHASTRI PARK-DWARKA PURI CKT (1ST CABLE)	BYPL	21.08.2019	ALL PHASE FAULTY. DIGGING IN PROGRESS
10.	33kV PARSVNATH MALL-KAILASH NAGAR CKT(1ST CABLE)	BYPL	21.08.2019	ALL PHASE FAULTY. DIGGING IN PROGRESS
11.	33kV PARSVNATH MALL-KAILASH NAGAR CKT(2ND CABLE)	BYPL	21.08.2019	R PHASE CABLE FAULTY
12.	33kV BAY -42 (IP - CONNAUGHT PLACE)	NDMC	26.07.2019	'B'PH. CABLE FAULTY
13.	220/66kV 160MVA PR.TR.-III AT 220kV VASANT KUNJ	DTL	26.04.2018	TRANSFORMER BURNT DUE TO FIRE. TO BE REPLACED.
14.	33kV BUS COUPLER AT KASHMERE GATE	DTL		TRIPPING COIL PROBLEM.
15.	220/33kV 100MVA PR. TR.-I AT 220kV RPH STN.	DTL	03.09.2018	TRIPPED ON BUCHOLZ AND DIFFERENTIAL RELAY. PR. TR FAILED.
16.	220/66kV 100MVA PR. TR.-I AT 220kV OKHLA STN.	DTL	27.09.2018	'Y' PH. WINDING DAMAGED. PR. TR FAILED.
17.	PATPARGANJ - 220/33kV 100MVA PR.TR.-I	DTL	10.01.2019	TR. DAMAGED. TO BE REPLACED.
18.	GAZIPUR:- 220/66/33kV 100MVA PR.TR.-I	DTL	22.03.2019	TRANSFORMER DISMANTLED AND SHIFTED TO RPH FOR TR.-II
19.	220KV BAMNAULI-DIAL CKT-I	DTL	22.08.2019	SHUT-DOWN FOR 4 DAYS FOR HTLS RECONDUCTORING WORK.
20.	HARSH VIHAR :- 220KV I/C-II AT HARSH VIHAR	DTL	20.08.2019	SHUT-DOWN FOR 15 DAYS FOR DGA TESTING OF ICT-III.
