

No. F.DTL/201/2022-23/DGM(OS)/F4/19

Date: 18.05.2022

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM (DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee


Sub: **Agenda for 2nd Delhi OCC Meeting (2022-23) to be held on 25.05.2022 at 11:00 A.M. through video conferencing.**

The 2nd Delhi OCC meeting (2022-23) is scheduled to be held on dt.- **25.05.2022, 11:00 A.M** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,


Hitesh Kumar
DGM(T)OS, DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 02/2022-23

Date : **25.05.2022**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 KV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 1st Delhi OCC meeting (2022-23) held on dated 25.04.2022.

The 1st Delhi OCC meeting (2022-23) was held on 25.04.2022 through video conferencing in accordance with the agenda circulated vide letter dt: 12.04.2022. Minutes of the OCC meeting were issued on 27.04.2022 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of June-2022.

DTL proposed planned shutdowns for the month of June-2022 (Annexure-I).

(OCC may deliberate)

3. Refusal of OCC approved shutdown of 66kV I/C-II alongwith 66kV Bus-II by BRPL at 220kV Najafgarh.

In the Ist Delhi OCC meeting held on 25.04.2022, shutdown of 66kV I/C-2 alongwith 66kV Bus-II was approved for the replacement of 66kV Bus-II, Isolator current transfer assembly at 220kV Najafgarh for 03.05.2022. One day prior intimation was also given to SLDC & BRPL via e-mail dated 02.05.2022. It was also confirmed telephonically with Sh. Kishore Babu (BRPL) and accordingly manpower(contractual) and material was made available on 03.05.2022 & 04.05.2022. However, the aforesaid OCC approved shutdown was denied by SLDC as BRPL failed to shift the load of 66kV Nangloi Ckt from Najafgarh which resulted into wastage of man power resources and also lead to severe damage to isolator of 66kV Bus-II due to excessive heating of current transformer assembly of isolator. In the past also, it is observed that BRPL failed to transfer its load of 66kV Nangloi Ckt form Najafgarh due to constraints at their end and shutdowns involving 66kV Nangloi Ckt at Najafgarh are seldom allowed by BRPL.

(OCC may deliberate)

4. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 12.05.2022
1.	220KV MEHRAULI- 66KV IGNOU	BRPL	06.05.22	'Y' PHASE CABLE FAULTY.
2.	400KV MUNDAKA-66KV NANGLOI CKT	BRPL	28.04.22	'Y' PHASE CABLE FAULTY.
3.	220KV PPK-2-HASTAL CKT-II	BRPL	04.05.22	'Y' PHASE SINGLE CABLE FAULTY.
4.	220KV IP BAY- 28- 33KV CONNAUGHT PLACE	NDMC	16.02.22	'Y' & 'B' PHASE CABLE TRIPPED ON E/F & O/C.
5.	220kV IP BAY 42- 33kV CONNAUGHT PLACE	NDMC	12.03.22	'Y' PHASE SINGLE CABLE FAULTY.
6.	220KV TRAUMA CENTRE-33kV RACE COURSE CKT	NDMC	15.04.22	'RYB' PHASE CABLE FAULTY.
7.	220KV TRAUMA CENTER-33KV AIIMS CKT-III	BRPL	29.01.22	UNDER BREAKDOWN.
8.	220KV PARK STREET - 66KV DMRC CKT.-I&-II	DMRC	19.10.21	SHUT DOWN FOR GRID SHIFTING WORK AT DMRC END.
9.	220KV SHALIMAR BAGH-66KV PP-I CKT-II	TPDDL	04.03.22	'Y' PHASE CABLE FAULTY.
10.	AT PEERAGARHI: - 220/33KV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFFERENTIAL. TX FAULTY.
11.	220KV LODHI ROAD - 33 KV VIDYUT BHAWAN, JLN STADIUM FEEDERS	DTL	29.11.21	AFFECTED DUE TO BOTH 33KV BUSES DEAD BECAUSE OF FIRE IN 33KV GIS
12.	220KV OKHLA- 100 MVA-IV	DTL	03.02.22	TRIPPED ON DIFFERENTIAL.
13.	400KV BAMNAULI- 315MVA ICT-I	DTL	03.03.22	ICT DISMENTLED & SHIFTED TO TIKRI KALAN AGAINST ICT-IV TO MEET LOAD REQUIREMENT OF SUMMER AT TIKRI KALAN.
